How to clear the device name listed on Eshell

Applies to:

Platform	*OS version*	*WinPAC/ViewPAC utility version*
WP-8x3x/ XP-8x4x	*All versions*	*All versions*
WP-5000	*All versions*	*All versions*
VP-23W1/ VP-25W1	*All versions*	*All versions*
VP-4131	*All versions*	*All versions*

Every time when Eshell searches a device, the device name will be added to a list without clearing. Therefore the list will be longer and longer (See “Diagram-1”) and become difficult to recognize which one is the right choice.





Diagram-1

The following is the solution:


Step 1: Copy “Eshell” folder to PC.
(There will be two files in it. One is ESHELL.EXE and another is registry_clear.exe
Download path:
CD:\napdos\wp-8x4x_ce50\PC_Tools\Eshell
http://ftp.icpdas.com/pub/cd/winpac/napdos/wp-8x4x_ce50/pc_tools/Eshell)

Step 2: Execute registry_clear.exe and click “Clear” button



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Step 3: After clearing device name, the Eshell windows shows to search device.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Revision History

Revision	Date	Description
1.0.1	2013/05/16	NEW: Added support information for WP-5000 and VP-4131.
1.0.0	2010/02/12	Initial release

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000