I-7567

USB To HART Converter

User's Manual

Warranty

All products manufactured by ICP DAS are under warranty regarding defective materials for a period of one year from the date of delivery to the original purchaser.

Warning

ICP DAS assumes no liability for damages resulting from the use of this product. ICP DAS reserves the right to change this manual at any time without notice. The information furnished by ICP DAS is believed to be accurate and reliable. However, no responsibility is assumed by ICP DAS for its use, or for any infringements of patents or other rights of third parties resulting from its use.

Copyright

Copyright 2011 by ICP DAS. All rights are reserved.

Trademark

The names used for identification only may be registered trademarks of their respective companies.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Table of Contents

1. Introduction 4
- 1.1 Features 4
- 1.2 Specifications 5

2. Hardware 7
- 2.1 Block Diagram 8
- 2.2 Pin Assignment of HART Port 9
  - 2.2.1 Pin Function Description 9
  - 2.2.2 HART Connection 9
- 2.3 Terminator Resistor Settings 12
- 2.4 Init / Normal Jumper 13
  - 2.4.1 Firmware Update Mode 13
  - 2.4.2 Firmware Operation Mode 14
- 2.5 LED Indication 15
  - 2.5.1 LED function 15
  - 2.5.2 LED indication Table 16
- 2.6 Cable Selection 16

3. Driver Installation 17
- 3.1 Install I-7567 Driver Automatically 17
- 3.2 Install I-7567 Driver Manually (Windows x86 Platform) 18
- 3.3 Install I-7567 Driver Manually (Windows x64 Platform) 21
- 3.4 Verify Driver Installation 23
- 3.5 Uninstall I-7567 Driver 24
- 3.6 Install I-7567 Driver in Windows10 25

4. HC_Tool Utility 30
- 4.1 Run Utility 30
- 4.2 Serial Port and HART Command Settings 30
  - 4.2.1 Serial port settings 30
  - 4.2.2 HART Frame Settings 31
- 4.3 Search HART devices 32
  - 4.3.1 Search HART devices automatically 32
  - 4.3.2 Search HART devices by manual 33
  - 4.3.3 Search HART devices 34
- 4.4 Send / Receive HART Frame (SRMsg) 36
- 4.5 HART Information Log (Data Log) 38
- 4.6 HART Configuration (HTCfg) 39
- 4.7 Module Configuration (ModCfg) 41

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5. FAQ 44
Q01 : How to use I-7567 to communicate with HART devices ?..... 44
Q02 : Does I-7567 support the API Library for HART ? 44
Q03 : I-7567 driver installation for Windows10 ? 44
Q04 : Set HART device address by using HART converter ? 44
Q05 : How to send HART command for writing (Ex: CMD51)?..... 46
Q06 : How to connect with HART OPC server?..... 48
Q07 : How to connect with HART FDT software?..... 51
Q08 : How to listen HART network communication by HART converter 60
6. Version History.....63

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1. Introduction

The I-7567 is a USB to HART converter specially designed as the master device of HART protocol. It allows users to access HART slaves via virtual COM-port of PC and the baud rate must be set as 1200 bps.

When connecting I-7567 to PC, PC will load the relevant device driver automatically (hot plug & play). Therefore, users can make data collection and processing of HART network easier and quicker by applying I-7567. In addition, by using the I-7567 utility, users can configure module and test HART communication easily.

The following is the application structure of the USB/HART modules.



1.1 Features

- Support HART Short/Long frame
- Support HART Burst mode.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

- Support point-to-point or multi-drop HART mode.
- Support connecting up to 15 HART slave devices.
- Allow two HART masters.
- Provide utility tool for module configuration and HART communication.
- No external power supply (powered by USB)
- Support firmware update via USB
- Provide PWR / Tx / Rx indication LED
- 4KV ESD Protection
- Selectable 250Ω load resistor (1/4W)

1.2 Specifications

[USB Spec.]

- Input port **:** USB (USB Type B)
- Compatibility **:** USB 1.1 and 2.0 standard
- Driver Supported **:** Windows 2000 / XP / Vista / 7 (32/64 bit)
- Virtual COM Parameter **: 1200** bps, **O**(odd parity), **8**(data bit), **1**(stop bit)

[HART Spec.]

- Channel **:** 1
- Connector **:** 2-pin screwed terminal-block
- Network **:** Point to Point or Multi-drop
- Baud Rate **: 1200** bps
- Frame **:** Short or Long
- Operates as a HART Master and supports all HART commands
- Support up to 15 HART slave devices
- Isolation Voltage **:** 3KVdc on the HART side

[Module Spec.]

- Dimensions **:** 108mm x 72mm x 35mm (H x W x D)
- Operating temperature **:** -25 to 75°C (-13 to 167°F);
- Storage temperature **:** -30 to 75°C (-22 to 167°F);
- Humidity **:** 5 to 95%, non-condensing;
- Indication LEDs **:**
  PWR LED **:** Module power status

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Tx LED : Data received from USB
Rx LED : Data received from HART port

[Utility Tool]

- Provide module configuration and HART communication easily and quickly.
- Provide HART devices search automatically.
- Provide diagnostic Information of HART device.
- Provide data logging for HART communication.

[Application]

- Current Measuring;
- Petrochemical Industry Application;
- Environment Monitoring;
- Tunnel Monitoring;
- Monitor system;
- Building Monitoring etc.;

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2. Hardware



Figure 2-1**:** Hardware externals of I-7567

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.1 Block Diagram

Figure 2-2 is a block diagram illustrating the functions on the I-7567 module. It provides the 3000Vrms Isolation in the HART interface site.




Figure 2-2: Block diagram of I-7567

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.2 Pin Assignment of HART Port




Figure 2-3**:** Pin Assignment on I-7567


2.2.1 Pin Function Description

Pin No.	Pin Name	Pin Function Description
1	-	N/A
2	-	N/A
3	-	N/A
4	HART+	HART+
5	-	N/A
6	-	N/A
7	HART-	HART-
8	-	N/A
9	-	N/A
10	-	N/A


2.2.2 HART Connection

The HART connection can be divided into the following two types **:**
(1) “Loop Power Source” Mode.
(2) “External Power Source” Mode.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Ex1 **:** Loop Power Source (Internal Resistance)




Ex2 **:** Loop Power Source (External Resistance)

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Ex3 **:** Loop Power Source (External Resistance)



Ex4 **:** External Power Source (Internal Resistance)

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.3 Terminator Resistor Settings

The DIP switch is used to provide HART network with 250 Ω (1/4 W) resistor. When it is set to “On”, the resistor will connect to HART network. Otherwise, it will disconnect the resistor from HART network. The default position of the DIP switch is in “On”.






Figure 2-5**:** Enable Internal Resistor. Figure 2-6**:** Disable Internal Resistor.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.4 Init / Normal Jumper

Open the shell of I-7567 and there is a jumper (JP1) on the PCB of I-7567 which is used for firmware operation or firmware updating function of I-7567 module.




Figure 2-7: Firmware Operation




Figure 2-8**:** Firmware Updating

2.4.1 Firmware Update Mode

Please follow the steps below to complete the firmware update process of I-7567.

(1) Set the jumper (JP1) to the firmware updating position as Figure 2-8 and reboot I-7567. Then I-7567 will work in the "Firmware Update Mode". In this mode, users can update the firmware of I-7567 module via USB and the I-7567 will become a "USB Mass Storage" device shown as Figure 2-9.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000





Figure 2-9**:** USB Mass Storage Device (G:\)

(2) Execute the "**FW_Update_Tool**" utility. (Download from http://ftp.icpdas.com/pub/cd/fieldbus_cd/hart/converter/i-7567/software/)
[1] Choose "**USB**" interface and "**USB Disk**" (e.g. **: J:**).
[2] Click "**Browser**" button to choose FW file (e.g. **: I7567_v1.00.fw**).
[3] Click "**Firmware Update**" button to start FW update process.
The result will show in "Firmware Update" field.



2.4.2 Firmware Operation Mode

In operation mode, users need to set the jumper (JP1) to the firmware operation position as Figure 2-7 and reboot I-7567. In this mode, users

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

can send / receive HART frame via USB port of PC.

2.5 LED Indication

There are three LEDs provided to indicate the status of I-7567. The Figure 2-10 is the illustration of these three LEDs.



Figure 2-10**:** LED position of I-7567

2.5.1 LED function

(1) PWR LED :

When I-7567 turned on, if it is in the firmware operation mode, then the PWR LED will be on immediately and permanently. If I-7567 is in the firmware update mode, then all the LED will turn off.

(2) Tx LED :

When I-7567 is receiving data from USB, then the Tx LED will flash until the data transmission completed.

(3) Rx LED :

When I-7567 is receiving the HART frame from HART device, then the Rx LED will flash until the data transmission completed.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.5.2 LED indication Table

LED Name	Power off	No Driver	FW Update	FW Operation	USB Port Data Received	HART Port Data Received
PWR LED	off	flash	off	on	on	on
Tx LED	off	flash	off	off	flash	off
Rx LED	off	flash	off	off	off	flash

2.6 Cable Selection

The HART bus is a balanced (differential) 2-wire interface running over a Shielded Twisted Pair (STP), Un-shielded Twisted Pair (UTP), or Ribbon cable. Please refer to the following table to decide what cable type, cable length, and terminator to use in the HART bus network.

No. Network Devices	Cable Capacitance – pf/ft (pf/m)			
	20 pf/ft (65 pf/m)	30 pf/ft (95 pf/m)	50 pf/ft (160 pf/m)	70 pf/ft (225 pf/m)
1	9,000 ft (2,769 m)	6,500 ft (2,000 m)	4,200 ft (1,292 m)	3,200 ft (985 m)
5	8,000 ft (2,462 m)	5,900 ft (1,815 m)	3,700 ft (1,138 m)	2,900 ft (892 m)
10	7,000 ft (2,154 m)	5,200 ft (1,600 m)	3,300 ft (1,015 m)	2,500 ft (769 m)
15	6,000 ft (1,846 m)	4,600 ft (1,415 m)	2,900 ft (892 m)	2,300 ft (708 m)

Allowable cable lengths for 1.0 mm (#18 AWG) shield twisted pair

Note: The AWG means a standard method used to measure wire. The numbering system works backwards from what people would think, the thicker (heavier) the wire, the lower the number.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3. Driver Installation

This section will show how to install the I-7567 USB/HART converter device driver under Windows 2000/XP and Win7. Users can download the I-7567 device driver from ICP DAS web site**:**
ftp://ftp.icpdas.com/pub/cd/fieldbus_cd/hart/converter/i-7567/usb_driver/

3.1 Install I-7567 Driver Automatically

[Step - 1]

Plug-in the I-7567 to PC first and Windows will detect the new device and shows the "Found New Hardware Wizard" screen prompting you to install the driver for the detected USB Device. Please click "Cancel" button to cancel driver installation manually shown as Figure 3-1.



2

Figure 3-1**:** New Hardware Wizard (1)

[Step - 2]

Execute "**icpusbconverter_drvinst_v1.2.exe**" file to install driver automatically and then click "Continue Anyway" button like Figure 3-2. After driver installation process finished, it will show the screen as Figure 3-3.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Figure 3-2**:** New Hardware Wizard (2)



Figure 3-3**:** Install I-7567 Driver Finished

3.2 Install I-7567 Driver Manually (Windows x86 Platform)

[Step - 1]

Please execute "**icpusbconverter_drvinst_v1.4.exe**" file first to install necessary driver files of I-7567 to system.

[Step - 2]

Plug in the I-7567 to PC and Windows will detect the new device and shows the "Found New Hardware Wizard" screen prompting you to install the driver for the detected USB Device. Please select "No, not this time" option and click "Next" button shown as Figure 3-4.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Figure 3-4**:** New Hardware Wizard (1)

[Step - 3]

Please select “install from a list or specific location (Advanced)” option and click “Next” button shown as Figure 3-5.



Figure 3-5**:** New Hardware Wizard (2)

[Step - 4]

Please select “Search for the best driver in these locations” option and check “include this location in the search:” checkbox then click “Browser” button to assign the I-7567 driver location - C:\WINDOWS\inf\ and then click “Next” button shown as Figure 3-6.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Figure 3-6**:** New Hardware Wizard (3)

[Step - 5]

Please click “Continue Anyway” button shown as Figure 3-7 .




Figure 3-7**:** New Hardware Wizard (4)

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


[Step - 6]

Please click “Finish” button to complete I-7567 device driver installation shown as Figure 3-8.




Figure 3-8: New Hardware Wizard (5)


3.3 Install I-7567 Driver Manually (Windows x64 Platform)




LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



[Assign the I-7567 driver to the "**I-7565-H1H2_DrvFile_v1.4**" folder]



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



3.4 Verify Driver Installation

This section will show how to verify whether the driver of I-7567 was properly installed. If the driver is installed successfully, then there will be a "Virtual COM Port" assigned by Windows. Please follow the steps below to check it.

Click "**Start**" → "**Settings**" → "**Control Panel**" and then double click on the "**System**" icon. Once the "**System Properties**" screen displayed, click on " **Hardware**" tab and then click on the "**Device Manager**" button. Double-click on **Ports (COM & LPT)** item. If the device driver was correctly installed, users can find the "ICPDAS I-7567 USB2HART" device listing and the "Virtual COM Port" number that Windows has assigned to the device is **COM3** shown as Figure 3-9.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 3-9**:** Virtual COM Port Number

3.5 Uninstall I-7567 Driver

Please follow the steps below to uninstall I-7567 device driver.

[Step - 1]

Click "**Start**" → "**Settings**" → "**Control Panel**" and then double click on the "**System**" icon. Once the "System Properties" screen displayed, click on " **Hardware**" tab and then click on the "**Device Manager**" button. Double-click on **Ports (COM & LPT)** item. Please find the "ICPDAS I-7567 USB2HART" device listing and click the right button on the mouse and choose "**Uninstall**" option shown as Figure 3-10.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 3-10**:** Uninstall I-7567 Driver (1)

[Step - 2]

Click "**OK**" button to complete I-7567 device driver un-installation like Figure 3-11. After that, the "ICPDAS I-7567 USB2HART" device listing will disappear on **Ports (COM & LPT)** item.




Figure 3-11**:** Uninstall I-7567 Driver (2)

3.6 Install I-7567 Driver in Windows10


Please follow the steps below

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1. Right click the【I-7567 USB2HART】option and choose【Update Driver Software ...】.




2. Click the【Browse my computer for driver software】option.




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3. Click the【Let me pick from a list of device drivers on my computer】 option.




4. Directly click the【Next】button。



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5. Click the【USB Serial Device】option and click the【Next】button.




6. Show the【Windows has successfully updated your driver software】message and it means that I-7567 driver installation is finished.



7. In the【Device Manager】, The【USB Serial Device (COMx)】will show up. (In Win10, I-7567 device message can't be shown.)

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4. HC_Tool Utility

HC_Tool utility is provided to configure all ICP DAS's HART converter modules (like I-7567 / I-7570) and transmit / receive HART frame for HART communication easily and quickly. HC_Tool utility can be downloaded from the ICP DAS web site **:** http://ftp.icpdas.com/pub/cd/fieldbus_cd/hart/converter/i-7567/software/.

4.1 Run Utility

Run the "**HC_Tool**", like Figure 4-1. If users can't run "HC_Tool", please install .NET Framework 3.5 first. (http://www.microsoft.com/downloads/details.aspx?familyid=333325FDAE52-4E35-B531-508D977D32A6&displaylang=en).




Figure 4-1**:** HC_Tool Utility

4.2 Serial Port and HART Command Settings

Please click "**Settings**" menu to open setting window of serial port and HART parameters like Figure 4-2.

4.2.1 Serial port settings

(1) Please select serial port no. of PC like Figure 4-2.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-2**:** Set Serial Port No.

(2) If using I-7570 module, please check “I-7570” item and select the communication parameters of PC serial port. Note, the settings of the communication parameters must be the same with those in I-7570.

4.2.2 HART Frame Settings

The following are the descriptions of HART command fields.

Auto Configure **:** (1) Enable **:** search HART devices automatically.
(2) Disable **:** search HART devices according to manual parameters.

Frame type **:** Select HART frame format (Short/Long).

Master type **:** Select Primary master or Secondary master.

Preambles **:** Select 5~20 bytes (0xFF) number.

Address **:** Select HART Polling Address (0~15).

Manufacturer ID**:** Manufacturer Identification Code

Device type **:** Manufacturer Device Type Code

Device ID **:** Manufacturer Device Identification Code.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-3**:** Set HART Frame Format

4.3 Search HART devices

4.3.1 Search HART devices automatically

Set the option of “Auto Configure” field to be “Enable” and the option of “Master type” field to be “Secondary” like Figure 4-4. Then HC_Tool utility will automatically search all HART devices by using HART short frame with “Secondary Master” identity.




Figure 4-4**:** Auto Configure - Enable

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4.3.2 Search HART devices by manual

Set the option of “Auto Configure” field to be “Disable” and then users can set the HART frame manually to search HART devices.

(1) If the option of “Frame type” field is “Short”, then “Master type”, “Preambles”, “Address” fields need to be configured like Figure 4-5.




Figure 4-5: Short frame settings

(2) If the option of “Frame type” field is “Long”, then “Master type”, Preambles”, “Manufacturer ID”, “Device type”, “Device ID” fields need to be configured like Figure 4-6.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-6**:** Long frame settings

If the setting of serial port and HART frame format is finished, please click the “OK” button. Then users can test the HART communication.

4.3.3 Search HART devices

(1) Click “**Open**” button to open the com port of PC like Figure 4-7. If com port open failed, please check the com port setting.




Figure 4-7**:** Click “Open” button

(2) Click “**Start**” button to search all HART devices and the result will be shown in the “Information” field like Figure 4-8.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-8**:** HART device Information

If the error message - “Search Device Failed !!” shows like Figure 4-9, please check HART network status and HART command format.




Figure 4-9**:** Search Device Failed

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4.4 Send / Receive HART Frame (SRMsg)

(1) Click “**SRMsg**” menu and it will open the HART command function window for HART communication like Figure 4-10.




Figure 4-10**:** SRMsg Function

(2) Please type the HART command in the ”Send Data” filed and click ”Send” button to send out the HART command like Figure 4-11.

[1] “**With Parity Check**” item **:**

When check the item, it will add the “check byte” automatically while sending the HART frame.

[2] “**Auto Scroll**” item **:**

When check the item, it will scroll the HART message field automatically to show the latest HART message information.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-11: Send HART Command

(3) When HART device responses the HART information, it will show in the “Receive Data” field like Figure 4-12. If error happened in HART communication, it will not show any message in the “Receive Data” field. Please check the HART command in the “Send Data” field if it is correct.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-12**:** Receive HART Command

4.5 HART Information Log (Data Log)

When using “SRMsg” or “Start” function for HART communication, all the HART command information will be logged in the “Data Log” function. Users can click “**Data Log**” item and all the HART communication information will be shown in “Log” field like Figure 4-13.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-13**:** HART Information Log

4.6 HART Configuration (HTCfg)

When HART devices are searched in HC_Tool, then users can use "**HTCfg**" function to configure HART devices like Figure 4-14. (Supported by HC_Tool v1.02 or newer)

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-14**:** HTCfg Item

The following are the function descriptions of “HTCfg” screen. (Like Figure 4-15)

(1) “**DevAddr**” Field**:** Assign the HART device for configuration.

(2) “**Response**” Field**:** Show the response message of HART configuration command.

(3) “**Universal**” Page**:** Choose the “Universal” command for configuration. (Support HART Command version v6.0)

(4) “**Common**” Page**:** Choose the “Common-Practice” for configuration. (Support HART Command version v6.0)

(5) “**Start**” Button**:** Trig to send the HART configuration command.

(6) “**Listen Mode**” item**:** Check it and click the “Start” button, HC_Tool will listen HART bus and show the received HART message information.

(7) “**HART RecvMsg Count**” Area**:** Show the total count of the received HART messages. (Including Master sending message and Slave response message)

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-15**:** HTCfg Screen

4.7 Module Configuration (ModCfg)

Click "**ModCfg**" item, it will show the below two options to open the module configuration screen of HART Converter like Figure 4-16.

(1) HC_Tool **:** v1.02 or newer supported.

(2) I-7567 **:** FW_v1.5 or newer supported.

(3) I-7570 **:** FW_v1.4 or newer supported

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-16: ModCfg Item

The following is the function description of “ModCfg”.

1. “For All” Option : (Like Figure 4-17)

Note : It is used for all HART Converter modules




Figure 4-17: “For All” Option - Configuration Screen

(1) “Get Module FW Version”:

=> Return the firmware version of HART converter module.

(2) “Reset Module”:

=> Reset HART converter module.

(3) “Get HART Send/Recv Count”:

=> Return the total count of the sending and receiving HART messages in HART converter module.

(4) “Reset HART Send/Recv Count”:

=> Reset the total count of the sending and receiving HART messages in HART converter module.

2. “For I-7570” Option : (Like Figure 4-18)

Note : It is just used to I-7570 module and make sure the I-7570 must run under “Config Mode” first.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




Figure 4-18**:** "For I-7570" Option - Configuration Screen

(1) "Set Serial Baudrate":

=> Set the baudrate parameters of the serial port in I-7570.




Figure 4-19**:** "Set Serial Baudrate" Function

(2) "Get Serial Baudrate":

=> Get the baudrate parameters of the serial port in I-7570.

(3) "Get Module Info":

=> Return the hardware information of I-7570. (Like**:** Firmware Version)

(4) "Reset Module (SWWDT)":

=> Reset I-7570. (Using Software WDT)。

(5) "Reset Module (HWWDT)":

=> Reset I-7570. (Using Hardware WDT)。

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5. FAQ

Q01 : How to use I-7567 to communicate with HART devices ?

A01:

1. Install I-7567 “USB Driver” and it will create the virtual com port. (refer to chapter 3)
2. Run “HC_Tool” utility to communicate with HART devices. (refer to chapter 4)

Q02 : Does I-7567 support the API Library for HART ?

A02:

No, it doesn’t. If users want to develop their own program to communicate with HART devices, please refer to the below suggestion.

(1) Familiar with HART protocol => Using HART Converter (like: I-7567 / I-7570 / I-7547) to send / receive HART command by yourself.

(2) Unfamiliar with HART protocol => Using HART Gateway (like: **HRT-710** (MB/RTU to HART) or **HRT-711** (MB/TCP to HART)) and users can easily and quickly access HART device information via Modbus communication.

Q03 : I-7567 driver installation for Windows10 ?

A03:

The detailed USB driver installation refers to the section 3.6.

Q04 : Set HART device address by using HART converter ?

A04: (2016/03/17)

Please follow the steps below.


(1) Just connect one HART device to one HART converter (like **:** I-7567 / I-7570 / I-7547).

(2) Run “HC_Tool” software.

[1] Open the ComPort。


[2] Click the “Start” button to search HART device automatically. As the figure below, the original address of the HART device is 0.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




[3] Click the “HTCfg” button to open HART configuration page.

[4] Choose the “HART device” for configuration. In the “Universal” page, click the “Cmd6” option and users can choose the new address of HART device (Example：set to 1). Then click the “Start” button to set the new address.




[5] After the setting for the new address is successful, the below message will show.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

[6] Click the “Start” button in the main page to search HART device again. Then the address of the HART device will be 1 as the below figure.



Q05 : How to send HART command for writing (Ex: CMD51)?

A05: (2017/04/05)

Please follow the steps below.

(1) Just connect one HART device to I-7567


(2) Run “HC_Tool” software.

[1] Open the ComPort。


[2] Click the “Start” button to search HART device automatically.

[3] Click the “HTCfg” button to open HART configuration page.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



[4] Choose the “HART device” for configuration. In the “Common” tab, select no.51 from the “Common-Practice Cmd” dropdown menu and users can enter dynamic variable assignments. Then click the “Start” button and check the responses.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Q06 : How to connect with HART OPC server?


A06: (2017/06/22)

HART OPC server provided by HCF can be downloaded from the following link:


https://fieldcommgroup.org/hart-server

After installation finished, open the HART OPC server and follow the steps below:


(1) Right click the HARTServer icon and choose Add Network



(2) Choose Single Serial Port option




(3) Open COM Port





LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

(4) After module added to the server successful, right click on the module icon and choose Add Device




(5) Choose polling address, and click OK for Instrument Properties window





Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

(6) Check device data: double click on the device icon added



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


Q07 : How to connect with HART FDT software?

A07: (2018/11/27)


ICP DAS converter can be used with FDT software. The following introduces 3 different FDT software and connection instruction.

(1) PACTware


[1] Add HART communication DTM (ComPort)




LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




[2] Add HART Device DTM (Generic HART DTM)




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



[3] Connect to HART device and show HART information



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

(2) FieldCare

[1] Enabling SQLFIELDCARE


SQL Active Directory Helper Service	Enabl...		已停用	Network S...
SQL Server (MSSQLSERVER)	Provi...	已啓動	自動	本機系統
SQL Server (SQLEXPRESS)	Provi...		手動	Network S...
SQL Server (SQLFIELDCARE)	Provi...	已啓動	手動	本機系統
SQL Server Agent (MSSQLSERVER)	Exec...		已停用	Network S...
SQL Server Agent (SQLEXPRESS)	Exec...		已停用	Network S...
SQL Server Agent (SQLFIELDCARE)	Exec...	已啓動	自動	Network S...
SQL Server Browser	Provi...	已啓動	自動	Local Serv...
SQL Server VSS Writer	Provi...	已啓動	自動	本機系統

[2] Add HART Communication DTM




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


[3] Connect to HART device and show HART information




(3) Siemens PDM

[1] Add HART Device DDL (ABB AS-800 as example)







LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




[2] Scan HART Device (ComPort)




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



[3] Check HART Device information



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Q08 : How to listen HART network communication by HART converter

A08: (2019/02/14)

HART converter is a good tool for analyzing and debugging HART network communication. To do so, please follow the instruction below:

Hardware:

ICP DAS HART converter *1


Software:

HC_Tool


Download from: ftp://ftp.icpdas.com.tw/pub/cd/fieldbus_cd/hart/converter/i-7567/software/

Steps:

1. Add HART converter to the existing HART network.




2. Make sure the loop resistance is 250 Ω, if HART converter's built-in resistor needs to turn off, please refer to section 2.3 of Terminator Resistor Settings.
3. Use HC_Tool to record HART communication frames
   (1) Simple data logging (does not affect existing communication)
   [1] "**Open**" Com Port and click the "**Data Log**" button



   [2] Click the "**Start Record**" button to record communication frames, and click "**Stop Record**" to end


Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




(2) Listen mode analysis data logging (may affect existing communication)

[1] "**Open**" Com Port and "**Start**" searching HART network device

[2] After finish searching device, click "**HTCfg**" button




[3] Tick "**Listen_Mode**" and click the "**Start**" button




[4] Click the "**Data Log**" button

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



[5] Click the "**Start Record**" button to record communication frames, and click "**Stop Record**" to end



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6. Version History

Ver.	Author	Date	Description
1.0	Bill	2011/03/17	1. First version
1.1	Edward	2012/03/02	1. Update content.
1.2	Edward	2012/12/20	**1. Update FW to v1.5** [1] Add “Config” Function. **2. Update HC_Tool to v1.02** [1] Add “Config” screen. [2] Add HART v6.0 Universal and Common-Practice Command. [3] Add “Listen” HART communication Function.
1.3	Edward	2015/10/30	1. Add the FAQ chapter. 2. Add the section 3.5 for I-7567 driver Installation in Win10.
1.4	Edward	2016/09/07	1. Add the Q04 of FAQ. 2. Add driver installation for Windows x64. (section 3.3)
1.5	Peter	2017/6/22	1. Add the Q05 of FAQ 2. Add the Q06 of FAQ
1.6	Peter	2018/11/27	1. Add the Q07 of FAQ
1.7	Peter	2019/02/14	1. Add the Q08 of FAQ

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000