PROFI-8855 User Manual

Warranty

All products manufactured by ICP DAS are warranted against defective materials for a period of one year from the date of delivery to the original purchaser.

Warning

ICP DAS assumes no liability for damages consequent to the use of this product. ICP DAS reserves the right to change this manual at any time without notice. The information furnished by ICP DAS is believed to be accurate and reliable. However, no responsibility is assumed by ICP DAS for its use, or for any infringements of patents or other rights of third parties resulting from its use.

Copyright

Copyright 2012 by ICP DAS Co., LTD. All rights reserved worldwide.

Trademark

The names used for identification only may be registered trademarks of their respective companies.

List of Revision

Date	Author	Version	Revision
2012/05/18	Ryan	1.00	Release
2013/09/09	Ryan	1.01	Support I-87061W

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Table of Content

List of Revision 1

1. Introduction 4

1.1. Overview 4

1.2. Applications 4

1.3. Features 5

1.4. Specifications 6

1.5. Modules Support 7

2. Hardware 8

2.1. PROFI-8855 Hardware Structure 8

2.2. Bus Wiring 9

2.3. PROFIBUS Cable and Transmission Distance 10

2.4. PROFIBUS Connector and Connection 10

2.5. Status Indicator 12

2.6. Watchdog mechanism 14

2.7. Node Address 15

2.8. Baud rate support 17

3. PROFIBUS DP System 18

3.1. The flow chart of the DP-slave 18

3.2. Power On / Reset – Rotary switch 19

3.3. Parameterization Data 20

3.4. Wait Configuration 26

3.5. Data Exchange 30

3.5.1 Numeric Representation 30

i-8K Series 30

i-87K Module 34

3.5.2 Byte Order and Data Address 42

i-8K Series & i-87K Series - General Digital Input/Output 42

i-87K Series - Digital Input w/ Counter 42

i-8K Series & i-87K Series – General Analog Input (w/o CJC Read/Offset) and Analog Output 43

i-8K Series & i-87K Series – General Analog Input (w/ CJC Read/Offset) 43

i-8K Series & i-87K Series – Counter/Frequency 45

Statistic Table of i-8K & i-87K 47

3.6. Diagnostic Message Report 51

3.7. Establish connection with PROFI-8855 54

3.8. Telegram cycle of data exchange 55

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4. PROFI-8855 Guideline (Based on SyCon) 57
4.1. Preprocessing 57
4.2. I/O View/Modify 62
5. GSD File 65

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1. Introduction


1.1. Overview

PROFIBUS is an open, digital communication system with a wide range of applications, particularly in the fields of factory automation and process automation. PROFIBUS is suitable for both fast, time-critical applications and complex communication tasks. PROFIBUS-DP is a famous protocol that enables simple, fast, cyclic and deterministic process data exchange between Master and assigned Slave.

The PROFI-8855 Remote I/O Unit is specially designed for the slave device of PROFIBUS DP protocol. It supports up to 8 I/O slots for ICPDAS i-8k High Profiles series, and i-87k High Profiles series I/O modules. In addition, we also provide the hot-swap function for i-87k High Profiles series I/O modules. To setup PROFIBUS network, users can choose and configure I/O modules by using the GSD file without any other setting tools.

1.2. Applications

- Industrial Automation
- Factory Automation
- Process Automation
- Etc…



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1.3. Features

Protocol & Hierarchy	DP-V0 Slave
Supports Transmission Rate (Kbps)	9.6, 19.2, 45.45, 93.75, 187.5, 500, 1500, 3000, 6000, 12000
Transmission Rate Setting	detected automatically
Address Setting	0~126 set by Rotary switches
Indicators	PWR, ERR, and RUN LEDs
I/O modules Configuration	Configured by GSD file
Supports I/O modules hot-swap	I-87K High Profile series
Network Isolation Protection	High Speed iCoupler
DC Isolation Protection	3000VDC on PROFIBUS side
Max. Input/Output Data Length	Up to 240Bytes each
Number of Channel of Diag.	39
Device-Related Diag. Type	Offline Detection

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1.4. Specifications

Model	PROFI-8855
CPU	80186, 80MHz
Flash	512K Bytes
SRAM	512K Bytes
EEPROM	2K Bytes
Watch Dog Timer	CPU Built-in
Com1	RS-232(Firmware update port)
PROFIBUS Interface	9-pin D-Sub(Female)
PROFIBUS Controller	Profichip VPC3+C
PROFIBUS Transceiver	ADI ADM2486 iCoupler Isolated Transceiver
Transmission Rate	Up to 12Mbps
I/O Expansion Slot	8 Slots
Power Requirement	10V ~ 30V
Power Supply	25W
Power Consumption	5W
Operating Temp.	-25℃ ~ +75℃
Storage Temp.	-40℃ ~ +80℃
Humidity	5% ~ 95%
Dimensions	312x91x132 mm (W x L x H)

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1.5. Modules Support

Type	Module Name	Type	Module Name
DI	i-8040W / i-8040PW / i-8051W / i-8052 W/ i-8053W / i-8053PW / i-8058W i-87040W / i-87046W / i-87051W / i-87052W / i-87053W / i-87053W-A5 / i-87058W	AI	i-8017HW i-87013W / i-87015W / i-87017W / i-87017W-A5 / i-87017RW / i-87017RCW / i-87018W / i-87018RW / i-87018ZW / i-87019RW
DO	i-8037W / i-8041W / i-8056W / i-8057W / i-8060W / i-8064W / i-8068W / i-8069W i-87041W / i-87057W / i-87064W / i-87065W / i-87066W / i-87068W / i-87069W	AO	i-8024W i-87024W / i-87028CW
DI/O	i-8042W / i-8050W / i-8054W / i-8055W / i-8063W i-87054W / i-87055W / i-87063W	Counter / Frequency	i-87082W

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2. Hardware


2.1. PROFI-8855 Hardware Structure



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.2. Bus Wiring

In order to minimize the reflection effect of the signal transmission, PROFIBUS device has to fit with an active terminal resistor at both first node and last node, as shown below



However, the number of station in PROFIBUS network is also restricted. According to PROFIBUS specification, it is up to 32 stations connected in a PROFIBUS segment. If more than 32 stations are connected, the PROFIBUS repeater must be used to link the individual bus segments.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.3. PROFIBUS Cable and Transmission Distance

The PROFIBUS cable with following properties has different transmission distance with respect to different transmission rate, shown in the following table


1. Impedance :135~165Ω
2. Capacity : lower than 30 pF/m
3. Loop resistance : lower than 110Ω/Km
4. Wire diameter : larger than 0.65mm
5. Core cross-section : larger than 0.34mm^2

Transmission Rate(Kbps)	Transmission Distance per Segment (meter)
9.6, 19.2, 45.45, 93.75	1200
187.5	1000
500	400
1500	200
3000, 6000, 12000	100

2.4. PROFIBUS Connector and Connection

➢ Connector

The connector of PROFI-8855 is shown below



Pin No.	Signal	Meaning
3	B-Line	Receive/Transmit data - plus
4	CNTR-P	Repeater control signal, RTS signal
5	GND	Power ground of active terminator
6	VP	Power 5 volt of active terminator
8	A-Line	Receive/Transmit data - minus

Note: The connector of PROFI-8855 has no terminators; users must use the


LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

connector with the terminator inside. The power of the terminator will provide by PROFI-8855 and Master.

➢ Connection

The PROFIBUS interface of the PROFI-8855 is a DB9 female connector. It is recommended to use a standard PROFIBUS cable and connector (DB9 male).


NOTE: Both side of the PROFIBUS cable which connected PROFI-8855 can add a core to reduce noise.





Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.5. Status Indicator



PROFI-8855 provide three types of status indicators, they are PWR LED (yellow), ERR LED (red) and RUN LED (green). When the power is supplied to PROFI-8855, PWR LED will turn on; Before PROFI-8855 gets into the data exchange state, ERR LED will turn on or flash; If CHK_CFG procedure is finished, RUN LED will turn on and ERR LED will turn off. The table below explains the relationship between linking status and recommend solutions.

Status Indicator	Meaning	Recommend solution
ERR ON & RUN OFF	PROFI-8855 is offline with no valid baud rate (offline mode*)	Check the address setting of PROFI-8855 and DP-master.
ERR Flash (0.1 Sec)	PROFI-8855 detects baud rate, but is still offline.(stop mode*)	Check the DP-Master is ready to communicate with PROFI-8855.
ERR Flash (0.5 Sec)	PROFI-8855 Prm is Fault.(Note 1)	Check the setting of PROFI-8855 in the master interface and make sure of the consistency.
ERR Flash (1 Sec)	PROFI-8855's Cfg is fault(Note 2)	Same as above
ERR ON & RUN ON	PROFI-8855 is in clear mode*.	Sets the DP-Master from clear mode to operation mode
ERR OFF & RUN ON	PROFI-8855 is in operation mode*.	
PWR & ERR Flash (1 Sec)	PROFI-8855 detect module(s) offline	Find the reason of the fault of corresponding module.

Note 1: "Prm Fault" is the abbreviation of "Parameter Fault"; It means that the number of parameter data which receive from DP-Master is not consistency

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

with DP-Slave (PROFI-8855), and it could due to the difference between module installation and master setting.

Note 2:“Cfg Fault” is the abbreviation of “Configuration Fault”, it means that the number of configuration data which receive from DP-Master is not consistency with DP-Slave (PROFI-8855), and it could due to the wrong order of installation.

Note *: there are four kinds of state in PROFIBUS DP Master.

1. Offline mode: Master not active on the bus.
2. Stop mode: Master only transmit token on the bus, and PROFIBUS DP is not active.
3. Clear mode: DP Master active, but all output are zero or set to fail-safe state.
4. Operate mode: DP Master full active.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.6. Watchdog mechanism

There is a built-in watchdog timer to monitor the linking status between PROFI-8855 and Master. In order to ensure an error-free connection, watchdog mechanism divides into three stages.

In the first stage, watchdog detects the start delimiter whether valid or not after the status of power supplied or system reset. If no SD1 telegram, SD2 telegram, or SD3 telegram are received completely, PROFI-8855 will changes the baud rate and continues detecting the correct baud rate. This stage is called “Baud Search”.


If the watchdog has detected a valid SD telegram, it goes into the second stage. In this stage, the watchdog monitors the integrity of the telegram. When watchdog timer is expired and PROFI-8855 doesn’t receive the complete telegram, PROFI-8855 will go to “Baud Search” state. This stage is called “Baud Control”.

After PROFI-8855 finishes initializing, PROFI-8855 waits for receiving the Set_Prm telegram. If PROFI-8855 receives the Set_Prm telegram with “WD_On=1”, then watchdog goes into DP_Control and monitors the telegram in Twd time. Otherwise, watchdog remains in the “Baud Control” state. This stage is called “DP_Control”.

Beside the watchdog mechanism mentioned above, i-87K modules with analog output or digital output have their own host watchdog to monitor the status of PROFI-8855. If PROFI-8855 lost the control of DP-Master (due to any unpredictable fault), it can’t send a specific watchdog clear command to flush the watchdog timer of i-87K modules. Then the module will go to safe mode. There are three kinds of safe-value in safe-mode, they are “retain last valid value”, “clear(zero)”, and “switch to substitute value”.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.7. Node Address



The figure shown above is the hexadecimal rotary switch. It dominates the node (station) address of PROFI-8855. The switch which labeled MSB is high nibble of address and the other one is low nibble of address.

According to PROFIBUS specification, the station address which from 0 to 126 is valid, and the address 126 is a special address that supports the remote setting SSA telegram from Class 2 DP-Master. PROFI-8855 uses the value of rotary switch as its address if the address is valid. While the address is invalid, PROFI-8855 will load the pre-saved value in EEPROM. Moreover, if the address is invalid (126) again, PROFI-8855 awaits the SSA telegram and applies it. (Note: If you want to clear the setting stored in EEPROM, you should adjust rotary switch to FF before the power is supplied).

Rotary Switch(dec)	Pre-saved address (EEPROM)	SSA Telegram	PROFI-8855 Station Address
0~125	Don't care	No Accept	Rotary Switch
126~254	0~125	No Accept	Pre-saved address (EEPROM)
	126 (default)	Accept with address 0~125	SSA Telegram and save address to EEPROM
	127~254	impossible	N/A
255	Clear to 126	Accept with address 0~125	SSA Telegram and save address to EEPROM

Note 1: Only one DP-Slave station with address 126 is permit in the bus.

Note 2: if you want to change the station address after data exchange had in

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

proceed, you must be let the PROFI-8855's Watchdog timeout and wait for 1 sec to release old address.

EX 1 : MSB => 0, LSB => B,
0 < (0*16+11) = 11 < 125 => Station Address = 11

EX 2 : MSB =>7, LSB => 9,
0 < (7*16+9) = 121 < 125 => Station Address = 121

EX 3 : MSB =>7, LSB => F, EEPROM => 15,
126 < (7*16+F) = 127 < 254
Station Address = Pre-saved address (EEPROM) = 15

EX 4 : MSB => 8, LSB => A, EEPROM => 126,
126 < (8*16+A) = 128 < 254
Station Address = SSA Telegram and save address to EEPROM

EX 5 : MSB =>F, LSB => F,
(F*16+F) = 255
Station Address = SSA Telegram and save address to EEPROM

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.8. Baud rate support


PROFI-8855 supports the entire baud rates of PROFIBUS. They are 9.6Kbps, 19.2Kbps, 45.45Kbps, 187.5Kbps, 500Kbps, 1.5Mbps, 3Mbps, 6Mbps, and 12Mbps. Because PROFI-8855 has a functionality of auto-detection for baud rates, users don't need to set the baud rate of PROFI-8855.

Note: Many baud rates only are supported by the particular cable or speed. For the detail, please refer to the above section "**PROFIBUS Cable and Transmission Distance"**

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3. PROFIBUS DP System

3.1. The flow chart of the DP-slave




Before DP-Slave changes to data exchange state, it employs some telegrams to initialize and establish the connection with DP-Master. These telegrams include Slave Diagnosis (Slave_Diag), Set Parameter (Set_Prm), Check Configuration (Chk_Cfg), Slave Diagnosis, Data Exchange (Data_Exch) and optional global control (GC). The explanation is as follows:

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.2. Power On / Reset – Rotary switch

While the power of PROFI-8855 has be supplied, PROFI-8855 loads the value of rotary switch first and decides to apply it or not by according to mechanism as follows. If the address of rotary switch is smaller than 126, PROFI-8855 applies the value directly. PROFI-8855 will load the pre-saved address stored in EEPROM, if the address of rotary switch is larger than 126 and smaller than 255. If the address stored in EEPROM is equal to 126 again, PROFI-8855 will wait for the Set_Slave_Add(SSA) telegram. A special address 255 is used for recovering address 126 to EEPROM in case of error SSA_telegram setting or other cases. Please refer to the more detail in the next chapter. The following figure shows the state flow of Wait SSA.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.3. Parameterization Data

In order to establish the connection completely, the DP-Slave should obtain enough information from the DP-Master. The DP-Slave uses the parameterization data to initialize the I/O module of DP-Slave. Parameters provided by DP-master divided into two parts in general: one is master-related parameter, and the other is module-related parameter. Master-related parameters provide the common setting between DP-Master and DP-Slave (e.g. Byte-Order, Diagnostic Period, etc). Module-related parameters provide the fundamental setting of the I/O modules in DP-Slave. If the parameters have been set in the DP-Slave successfully, DP-state will proceed to wait configuration, otherwise it will return to wait parameter.

PROFI-8855 also has two kinds of parameter data. One kind of parameters is the system data, and the other is I/O module data. In i-8K modules, there is no I/O module parameter except for i-8017HW, i-8024W and i-8050W. In i-87K modules, every module has their own parameters to determine the data format and operation mode. We will describe the I/O modules plugged in PROFI-8855 individually in next section.

System parameters

- **Byte-Order**

  The memory allocation in PROFI-8855 is according to the slot id. Therefore, the I/O module in slot 0 will allocate memory first, slot 1 in next and so on. Byte order is an important factor related to the memory allocation. Big-endian byte order (Motorola format) allocates more significant byte in lower memory address. On the other hand, little-endian Byte order (Intel format) allocates more significant byte in higher memory address.

  For example, the integer which value is 0x0400(hex) will allocates 0x40(hex) in the first byte of the memory allocated to the integer and 0x00(hex) in the second byte.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Module parameters for I-8K module

i-8017HW

i-8017HW is a standard analog input module; it requires the data of “Data Format”, “Data Range” and “Diag Enable” to establish the connection completely. In order to reduce the length of parameter data, PROFI-8855 encapsulates this information into one byte for one channel. So there are 8 bytes data for i-8017HW(Differential) and 16 bytes for i-8017HW(Single-ended).

Data range is about the measurement type (voltage, current) and the measurement range (-10v to 10v or 4mA to 20mA). Data format can be selected either engineer unit format or hexadecimal format. Finally, “Diag Enable” is a flag that determines whether diagnostic message will report or not.

i-8024W:

i-8024W is similar to i-8017HW , please refer to i-8017HW .

i-8050W:

i-8050W is a programmable digital input/output module with sixteen programmable I/O. It is different from the other digital modules. Before using i-8050W, user must configure it first. PROFI-8855 provides a 2-byte length to configure the i-8050W. The first byte controls the direction (Input or Output) of channel 15 to channel 8, and the second byte correspond to channel 7 to channel 0. As mentioned above, digit ‘1’ represents input and ‘0’ represents output.

Module Parameter for i-87K module:

Before using the i-87K module with PROFI-8855, it must be initialized the configuration. Unlike the i-8K module, i-87K module uses the serial interface to communicate with MCU. In the following section, we will introduce the module parameters of i-87K briefly.

1. Type Code: every operation mode has an unique type code in the i-87K module. Its range is from 0 to 128. This code dominates the module’s behaviors which are voltage input, current input, temperature input, digital I/O and so on. In general, most AI modules support parts of type code. For example, i-87017W

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

supports type code 0x08 to 0x0D for voltage input.

2. Data Format: PROFI-8855 provides four kinds of data format to broaden the applicability. They are engineer unit format, Hexadecimal format, percentage of full scale and Ohm in engineer unit. Most i-87K modules support the first three formats, and the last format is only supported by i-87013W and i-87015W.

Besides the essential parameter mentioned above, a number of modules have some self-related parameter.

Analog Module, e.g. i-87013W, i-87015W, i-87017W, i-87017RW, i-87017RCW, i-87017W-A5, i-87018W, i-87018RW, i-87018ZW, i-87019RW, i-87024 and i-87028CW, they all have an additional parameter “Diag Enable” to determine whether diagnosis report or not.

Among the analog input modules, most of them share a common type code. It means that every channel operates at the same mode, and this manner will narrow its applicability. ICP DAS provides a number of modules supporting individual channel configuration to solve this problem; They are i-87015W、i-87018ZW and i-87019RW.

In **Counter/Frequency module** i-87082W, type-code is fixed to 0x80, and its parameters are divided into several parts, as shown below:

1. Frequency Gate Time: Frequency gate time is also called “sampling period”. It controls the signal-passing time. The counter takes effect during this period only, when AC-signal is supplied. After this period has elapsed, PROFI-8855 transforms this count into appropriate count value or frequency value immediately and available in INPUT buffer.

2. High Level Trigger Voltage: It is the threshold of the minimum input voltage of logic “1” at the non-isolated input. The default value is 24(2.4 volt).

3. Gate Mode: Gate mode is like frequency gate time. The difference between them is that gate mode is for counter mode and frequency gate time is for frequency mode. Gate mode with

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

0 is low active which means the count-signal take into account if GATE pin is connected a logic “0”. Gate mode with 1 is like Gate mode with 0, but the mode is high active. Gate mode with 2 disables gate control and GATE pin is regardless.

4. Low Level Trigger Voltage: It is the threshold of the maximum input voltage of logic “0”at the non-isolated input. The default value is 8(0.8 volt).

5. Input Mode: This parameter is used to define the input as isolated or non-isolated. The Isolated input is used to isolate the electrical interference. The Isolated input uses photo-couple to pass the On/Off signal to i-87082W and the non-isolated input is directly accepted the input signal into the i-87082W.

6. Filter Enabled: Digital filter is provided by i-87082W, and it can be enabled by setting this parameter to “Enable”.

7. Trigger Type of Channel 1 & 0: Trigger type is a parameter that control the action of “Clear”, ”Start”, “Stop” command. The default setting is Rising Edge Trigger. i-87082W can accept command only when the state of the function selection is changed from 0(Disable) to 1(Start) or 2(Stop) or 3(Clear). On the other hand, i-87082W accepts command only with the value of the function selection larger than 0 when the setting is High Level Trigger,.

8. High Level Pulse Width: This parameter is an important factor of digital filter. It dominates the minimum pulse width that i-87082W can accept. If pulse width is shorter than that, it will be filtered. Otherwise, it can pass through. For example, if there is a signal 200 KHz with duty cycle 50% and high level pulse width is set to 3us, then this measurement signal is limited in 166 KHz. The Signal has been filtered, because the signal with 200 KHz has the pulse width of 2.5us and it is smaller than 3us.

   Note: Formula of Maximum Frequency is equal to the inverse of pulse width divided by duty cycle.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

9. Low Level Pulse Width: This parameter is like High Level Pulse width. Please refer to High Level Pulse Width.

10. Preset Count of Counter N: The preset count is a parameter with four bytes length. It will be load when clear command is issued or module reset. The range of this parameter is between 0 and 2^{32}. Notice that this setting will not be cleared by clear command. It only can be modified by Set_Prm telegram.

11. Maximum Count of Counter N: Maximum count is the threshold of the overflow. If the count value reaches this threshold, the channel will overflow and halt for clear. Otherwise, the counter continues counting.
    Note: When overflow flag is not cleared by users, it will be held this status until clear command is issued. As soon as the channel overflows, the diagnostic message will be reported.

Module Parameter for Output modules:

The output modules consist of Analog Output modules and Digital Output modules. They are different from the Input modules. Output modules have the Safe Value output mechanism. They can output the Safe Value while PROFI-8855 has been changed to stop mode (or offline mode). The safe value can make sure of the correctness of operating. There are three modes in safe value for users: Retain Last Value, Clear Output and Switch to Substitute Value.


Retain Last Value is that PROFI-8855 retain the last valid output value for the corresponding channel.

Clear Output clear the corresponding channel to analog zero volt, analog zero ampere or digit logic “0”.

Substitute Value follows Safe mode selection in module parameter, it is setting by user, it must be obey the data range of corresponding data format and type-code.

The following figure shows the state flow of Wait Parameter.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.4. Wait Configuration

Configuration data is consisting of module-identifier. The main purpose is to check the configuration data from DP-Master against the stored one in PROFI-8855. If these configuration data is coincident between PROFI-8855 and DP-master, the DP-mode of PROFI-8855 will proceed from wait configuration to data exchange. Otherwise, PROFI-8855 will report “Cfg Fault” and change DP-mode to wait parameter again.

Configuration Data

The configuration data specifies the number of input and output bytes of PROFI-8855. PROFI-8855 applies this information to allocate appropriate number of memory space for the module plugged in I/O expansion slot on PROFI-8855. The maximum number of Input and output byte are 240 bytes each. It is not permitted to exceed this quantity. The following table shows the module name and corresponding input byte, output byte and configuration code.

Module name	Input Length	Output Length	Cfg Code
i-8017HW – D[1]	16 Byte(8*2)	0	0x57
i-8017HW – S[2]	32 Byte(16*2)	0	0x5F
i-8024W	0	8 Byte	0x63
i-8037W	0	2 Byte	0x21
i-8040W	4 Byte	0	0x13
i-8040PW	4 Byte	0	0x13
i-8041W	0	4 Byte	0x23
i-8042W	2 Byte	2 Byte	0x31
i-8050W	2 Byte	2 Byte	0x31
i-8051W	2 Byte	0	0x11
i-8052W	1 Byte	0	0x10
i-8053W	2 Byte	0	0x11
i-8053PW	2 Byte	0	0x11
i-8054W	1 Byte	1 Byte	0x30
i-8055W	1 Byte	1 Byte	0x30
i-8056W	0 Byte	2 Byte	0x21
i-8057W	0 Byte	2 Byte	0x21

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

i-8058W	1 Byte	0	0x10
i-8060W	0	1 Byte	0x20
i-8063W	1 Byte	1 Byte	0x30
i-8064W	0	1 Byte	0x20
i-8068W	0	1 Byte	0x20
i-8069W	0	1 Byte	0x20
i-87013W	8 Byte(4*2)	0	0x53
i-87015W	14 Byte(7*2)	0	0x56
i-87017(R)W	16 Byte(8*2)	0	0x57
i-87017RCW	16 Byte(8*2)	0	0x57
i-87017W-A5	16 Byte(8*2)	0	0x57
i-87018(R)W	16 Byte(8*2)	0	0x57
i-87018(R)W (w/ CJC Read/Offset)	18 Byte(8*2+2[@1])	2 Byte(0+2[@2])	0x57,0xC0,0x01, 0x40
i-87018ZW	20 Byte(10*2)	0	0x59
i-87018ZW (w/ CJC Read/Offset)	22 Byte (10*2+2[@1])	3 Byte(0+3[@2])	0x59,0xC0,0x02, 0x40
i-87019RW	16 Byte(8*2)	0	0x57
i-87019RW (w/ CJC Read/Offset)	18 Byte(8*2+2[@1])	3 Byte(0+3[@2])	0x57,0xC0,0x02, 0x40
i-87024W	0	8 Byte(4*2)	0x63
i-87028CW	0	16 Byte(8*2)	0x67
i-87040W	4 Byte	0	0x13
i-87040W(w/ Cnt)	68 Byte(4+32*2)	5 Byte(0+4)	0x13,0xC0,0x03, 0x5F
i-87041W	0	4 Byte	0x23
i-87046W	2 Byte	0	0x11
i-87046W(w/ Cnt)	34 Byte(2+16*2)	2Byte(0+2)	0x11,0xC0,0x01, 0x4F
i-87051W	2 Byte	0	0x11
i-87051W(w/ Cnt)	34 Byte(2+16*2)	2 Byte(0+2)	0x11,0xC0,0x01, 0x4F
i-87052W	1 Byte	0	0x10
i-87052W(w/ Cnt)	17 Byte(1+8*2)	1 Byte(0+1)	0x10,0xC0,0x00, 0x47
i-87053W	2 Byte	0	0x11
i-87053W(w/ Cnt)	34 Byte(2+16*2)	2 Byte(0+2)	0x11,0xC0,0x01, 0x4F


LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

i-87054W	1 Byte	1 Byte	0x30
i-87054W(w/ Cnt)	17 Byte(1+8*2)	2 Byte(1+1)	0x30,0xC0,0x00, 0x47
i-87055W	1 Byte	1 Byte	0x30
i-87055W(w/ Cnt)	17 Byte(1+8*2)	2 Byte(1+1)	0x30,0xC0,0x00, 0x47
i-87057W	0	2 Byte	0x21
i-87058W	1 Byte	0	0x10
i-87058W(w/ Cnt)	17 Byte(1+8*2)	1 Byte(0+1)	0x10,0xC0,0x00, 0x47
i-87063W	1 Byte	1 Byte	0x30
i-87063W(w/ Cnt)	9 Byte(1+4*2)	2 Byte(1+1)	0x30,0xC0,0x00, 0x43
i-87064W	0	1 Byte	0x20
i-87065W	0	1 Byte	0x20
i-87066W	0	1 Byte	0x20
i-87068W	0	1 Byte	0x20
i-87069W	0	1 Byte	0x20
i-87082W	9 Byte	1 Byte(1 OR 1)	0x53,0x10,0x20

-D[1] means single-end input mode
-S[2] means differential input mode
- Data length of analog input module = channel number * data length per channel.
-Data length of digital input module = the length of basic input data + channel number * data length of counter per channel.
-Data length of digital output module = the length of basic output data + optional data length of clear command.
-OR means DO data have combined with Clear command into one byte.
-@[1] means the data length of CJC temperature.
-@[2] means the data length of CJC offset setting command.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

The figure is shown below the state flow of Wait Configuration.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.5. Data Exchange

After the parameterization and configuration processes have been accomplished, PROFI-8855 exchanges I/O data with the DP-Master cyclically. In following section, we introduce the Numeric Notation and Byte Order briefly.

3.5.1 Numeric Representation

Among Analog Input modules or Analog Output modules, there are many numeric representations, include Engineer-Unit, Hexadecimal, Percentage of Full Scale and Ohm in Engineer-Unit. We will introduce the numeric representation in i-8K module and i-87K module.

i-8K Series

Analog Input Module (i-8017HW)

+/- 10 V ：

The range for Engineer-Unit: -10000~10000(mV)
The range for 2's complement hexadecimal: 0000~1FFF (0v ~ 10v), 2000~3FFF (-10v~1.22mV)
Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{10000} \times 8192 - 1 \qquad \text{if } 0 \le EngineerValue \le 10000$$

$$HexValue = \frac{EngineerValue}{10000} \times 8192 + 16384 \qquad \text{if } -10000 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
+10v(Engineer mode)	10000	0x2710
0v(Engineer mode)	0	0x0000
-10v(Engineer mode)	-10000	0xD8F0
+10v(Hex mode)	8191	0x1FFF
+5v(Hex mode)	4095	0x1000
0v(Hex mode)	0	0x0000
-5v(Hex Mode)	12288	0x3000
-10v(Hex mode)	8192	0x2000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

+/- 5 V ：

The range for Engineer-Unit: -5000~5000(mV)
The range for 2's complement hexadecimal: 0000~1FFF (0v ~ 5v), 2000~3FFF (-5v~0.61mV)
Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{5000} \times 8192 - 1 \qquad \text{if } 0 \le EngineerValue \le 5000$$

$$HexValue = \frac{EngineerValue}{5000} \times 8192 + 16384 \qquad \text{if } -5000 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
+5v(Engineer mode)	5000	0x1388
0v(Engineer mode)	0	0x0000
-5v(Engineer mode)	-5000	0xEC78
+5v(Hex mode)	8191	0x1FFF
+2.5v(Hex mode)	4095	0x1000
0v(Hex mode)	0	0x0000
-2.5v(Hex mode)	12288	0x3000
-5v(Hex Mode)	8192	0x2000

+/- 2.5 V ：

The range for Engineer-Unit: -2500~2500(mV)
The range for 2's complement hexadecimal: 0000~1FFF (0v ~ 2.5v), 2000~3FFF (-2.5v~0.3mV)
Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{2500} \times 8192 - 1 \qquad \text{if } 0 \le EngineerValue \le 2500$$

$$HexValue = \frac{EngineerValue}{2500} \times 8192 + 16384 \qquad \text{if } -2500 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
+2.5v(Engineer mode)	2500	0x09C4
0v(Engineer mode)	0	0x0000
-2.5v(Engineer mode)	-2500	0xF63C
+2.5v(Hex mode)	8191	0x1FFF
+1.25v(Hex mode)	4095	0x1000
0v(Hex mode)	0	0x0000
-1.25v(Hex mode)	12288	0x3000
-2.5v(Hex Mode)	8192	0x2000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

+/- 1.25 V ：

The range for Engineer-Unit: -1250~1250(mV)
The range for 2's complement hexadecimal: 0000~1FFF (0v ~ 1.25v), 2000~3FFF (-1.25v~0.15mV)
Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{1250} \times 8192 - 1 \qquad \text{if } 0 \le EngineerValue \le 1250$$

$$HexValue = \frac{EngineerValue}{1250} \times 8192 + 16384 \qquad \text{if } -1250 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
+1.25v(Engineer mode)	1250	0x04E2
0v(Engineer mode)	0	0x0000
-1.25v(Engineer mode)	-1250	0xFB1E
+1.25v(Hex mode)	8191	0x1FFF
+0.675v(Hex mode)	4095	0x1000
0v(Hex mode)	0	0x0000
-0.675v(Hex mode)	12288	0x3000
-1.25v(Hex Mode)	8192	0x2000

+/- 20 mA ：

The range for Engineer-Unit: -20000~20000(mV)
The range for 2's complement hexadecimal: 0000~1FFF (0mA ~ 20mA), 2000~3FFF (-20mA ~ -2.44uA)
Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{20000} \times 8192 - 1 \qquad \text{if } 0 \le EngineerValue \le 20000$$

$$HexValue = \frac{EngineerValue}{20000} \times 8192 + 16384 \qquad \text{if } -20000 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
20mA(Engineer mode)	20000	0x4E20
10mA(Engineer mode)	10000	0x2710
0v(Engineer mode)	0	0x0000
20mA(Hex mode)	8191	0x1FFF
10mA(Hex mode)	4095	0x1000
0v(Hex mode)	0	0x0000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Analog output module (I-8024W)：

+/- 10 V ：

The range for Engineer-Unit: -10000~10000(mV)
The range for 2's complement hexadecimal: 0000~7FFF (0v ~ 10v), 8000~FFFF (-10v~0.3mV)
Conversion from Engineer-Unit to two's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{10000} \times 32768 - 1 \qquad \text{if } 0 \le EngineerValue \le 10000$$

$$HexValue = \frac{EngineerValue}{10000} \times 32768 + 65536 \qquad \text{if } -10000 \le EngineerValue < 0$$

Measurement Value	Decimal	Hexadecimal
10v(Engineer mode)	10000	0x2710
0v(Engineer mode)	0	0x0000
-10v(Engineer mode)	-10000	0xD8F0
10v(Hex mode)	32767	0x7FFF
0v(Hex mode)	0	0x1000
-10v(Hex mode)	-32768	0x8000

+ 20mA ：

The range for Engineer-Unit: -20000~20000(mV)
The range for 2's complement hexadecimal: 0000~7FFF (0v ~ +20mA)

Conversion from Engineer-Unit to 2's complement hexadecimal:

$$HexValue = \frac{EngineerValue}{20000} \times 32768 - 1$$

Measurement Value	Decimal	Hexadecimal
20mA(Engineer mode)	20000	0x4E20
0mA(Engineer mode)	0	0x0000
20mA(Hex mode)	32767	0x7FFF
0mA(Hex mode)	0	0x0000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

i-87K Module

i-87K modules are serial communication-based I/O modules, they provide various data formats. For example, Engineer-Unit, Percentage of Full Scale, 2's Complement Hexadecimal and Ohm format are supported in these modules. The relationship between the type of measurement and the unit of measurement is represented in the following table.

Type	Conditions	Unit
Voltage/Current	-10V≦Voltage≦10V 20mA≧Current≧-20mA	milli-Volt(mV) micro-Ampere(μA)
Voltage	Voltage≧10V or Voltage≦-10V	Volt(V)
Temperature	RTD/Pt/Ni/Cu-RTD/Thermocouple	0.1 Degree Celsius
Resistor	RTD/Pt/Ni/Cu-RTD/Thermocouple	0.1 Ohm(0.1 Ω)

i-87013W and **i-87015W** Analog Input Module

Type-Code	Input Range	Data Format	Max.	Min
20	Pt-100 (a = 0.00385) -100°C to 100°C	Engineer Unit	+1000	-1000
		% of FSR	+10000	-10000
		2's complement HEX	7FFF	8000
		Ohm	+1385	+0602
21	Pt-100 (a = 0.00385) 0°C to 100°C	Engineer Unit	+1000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+1385	+1000
22	Pt-100 (a = 0.00385) 0°C to 200°C	Engineer Unit	+2000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+1758	+1000
23	Pt-100 (a = 0.00385) 0°C to 600°C	Engineer Unit	+6000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+3135	+1000
24	Pt-100 (a = 0.003916) -100°C to 100°C	Engineer Unit	+1000	-1000
		% of FSR	+10000	-10000
		2's complement HEX	7FFF	8000
		Ohm	+1391	+0595

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

25	Pt-100 (a = 0.003916) 0°C to 100°C	Engineer Unit	+1000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+1391	+1000
26	Pt-100 (a = 0.003916) 0°C to 200°C	Engineer Unit	+2000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+1771	+1000
27	Pt-100 (a = 0.003916) 0°C to 600°C	Engineer Unit	+6000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+3172	+1000
28	Nickel 120 -80°C to 100 °C	Engineer Unit	+1000	-0800
		% of FSR	+10000	-08000
		2's complement HEX	7FFF	999A
		Ohm	+2006	+1206
29	Nickel 120 0°C to 100°C	Engineer Unit	+1000	+0000
		% of FSR	+10000	+00000
		2's complement HEX	7FFF	0000
		Ohm	+2006	+1206
2A	Pt-1000(a = 0.00385) -200°C to 600°C	Engineer Unit	+6000	-2000
		% of FSR	+10000	-03333
		2's complement HEX	7FFF	D556
		Ohm	+31371	+01852
2B[*1]	Cu 100 (a = 0.00421) -20°C to 150°C	Engineer Unit	+1500	-0200
		% of FSR	+10000	-01333
		2's complement HEX	7FFF	EEEF
		Ohm	+1631	+0915
2C[*1]	Cu 100 a = 0.00421 0°C to 200°C	Engineer Unit	+2000	0000
		% of FSR	+10000	-00000
		2's complement HEX	7FFF	0000
		Ohm	+1677	+0903
2D[*1]	Cu 1000 a = 0.00421 -20°C to 150°C	Engineer Unit	+1500	-0200
		% of FSR	+10000	-01333
		2's complement HEX	7FFF	EEEF
		Ohm	+16317	+09156
2E[*2]	Pt 100 a = 0.00385 -200°C to +200°C	Engineer Unit	+2000	-2000
		% of FSR	+10000	-10000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

		2's complement HEX	7FFF	8000
		Ohm	+1758	+0184
2F*2	Pt 100 a = 0.003916 -200°C to +200°C	Engineer Unit	+2000	-2000
		% of FSR	+10000	-10000
		2's complement HEX	7FFF	8000
		Ohm	+1771	+0171
80*2	Pt 100 a = 0.00385 -200°C to +600°C	Engineer Unit	+6000	-2000
		% of FSR	+10000	-03333
		2's complement HEX	7FFF	D556
		Ohm	+3135	+0184
81*2	Pt 100 a = 0.003916 -200°C to +600°C	Engineer Unit	+6000	-2000
		% of FSR	+10000	-03333
		2's complement HEX	7FFF	D556
		Ohm	+3172	+0171

* 1: Type 2B, 2C and 2D are only available with i-87015W.

* 2: Type 2E, 2F, 80 and 81 are only available with the i-87015W firmware version A1.10 and later, i-87013W firmware version B1.3 and later.

i-87017W/i-87017RW Analog Input Module

Type-Code	Input Range	Data Format	Max.	Min
08	-10V to +10V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
09	-5V to +5V	Engineer Unit	+50000	-50000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0A	-1V to +1V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0B	-500mV to +500mV	Engineer Unit	+500	-500
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0C	-150mV to +150mV	Engineer Unit	+150	-150
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0D	-20mA to +20mA	Engineer Unit	+20000	-20000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000

i-87017RCW Analog Input Module

Type-Code	Input Range	Data Format	Max.	Min
07	-4mA to +20mA	Engineer Unit	+04000	+20000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0D	-20mA to +20mA	Engineer Unit	+20000	-20000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
1A	+0A to +20mA	Engineer Unit	+00000	+20000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000

i-87018W/i-87018RW Analog Input Module

Type-Code	Input Range	Data Format	Max.	Min
00	-15mV to +15mV	Engineer Unit	+15	-15
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
01	-50mV to +50mV	Engineer Unit	+50	-50
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
02	-100mV to +100mV	Engineer Unit	+100	-100
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
03	-500mV to +500mV	Engineer Unit	+500	-500
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
04	-1V to +1V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
05	-25V to +25V	Engineer Unit	+25000	-25000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
06	-20mA to +20mA	Engineer Unit	+20000	-20000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0E	J Type	Engineer Unit	+7600	-2100
		% of FSR	+10000	-02763
		2's Complement HEX	7FFF	DCA2
0F	K Type	Engineer Unit	+13720	-02700
		% of FSR	+10000	-01968
		2's Complement HEX	7FFF	E6D0
10	T Type	Engineer Unit	+4000	-2700
		% of FSR	+10000	-06750
		2's Complement HEX	7FFF	A99A
11	E Type	Engineer Unit	+10000	-02700
		% of FSR	+10000	-02700
		2's Complement HEX	7FFF	DD71
12	R Type	Engineer Unit	+17680	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
13	S Type	Engineer Unit	+17680	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
14	B Type	Engineer Unit	+18200	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
15	N Type	Engineer Unit	+13000	-02700
		% of FSR	+10000	-02077
		2's Complement HEX	7FFF	E56B
16	C Type	Engineer Unit	+23200	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
17	L Type	Engineer Unit	+8000	-2000
		% of FSR	+10000	-02500
		2's Complement HEX	7FFF	E000
18	M Type	Engineer Unit	+1000	-2000
		% of FSR	+05000	-10000
		2's Complement HEX	4000	8000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

19	L Type DIN43710	Engineer Unit	+9000	-2000
		% of FSR	+10000	-02222
		2's Complement HEX	7FFF	E38F

i-87019RW Analog Input Module

Type-Code	Input Range	Data Format	Max.	Min
00	-15mV to +15mV	Engineer Unit	+15	-15
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
01	-50mV to +50mV	Engineer Unit	+50	-50
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
02	-100mV to +100mV	Engineer Unit	+100	-100
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
03	-500mV to +500mV	Engineer Unit	+500	-500
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
04	-1V to +1V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
05	-2.5V to +2.5V	Engineer Unit	+25000	-25000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
06	-20mA to +20mA	Engineer Unit	+20000	-20000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
08	-10V to +10V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
09	-5V to +5V	Engineer Unit	+50000	-50000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0A	-1V to +1V	Engineer Unit	+10000	-10000
		% of FSR	+10000	-10000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

		2's Complement HEX	7FFF	8000
0B	-500mV to +500mV	Engineer Unit	+500	-500
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0C	-150mV to +150mV	Engineer Unit	+150	-150
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0D	-20mA to +20mA	Engineer Unit	+20000	-20000
		% of FSR	+10000	-10000
		2's Complement HEX	7FFF	8000
0E	J Type	Engineer Unit	+7600	-2100
		% of FSR	+10000	-02763
		2's Complement HEX	7FFF	DCA2
0F	K Type	Engineer Unit	+13720	-02700
		% of FSR	+10000	-01968
		2's Complement HEX	7FFF	E6D0
10	T Type	Engineer Unit	+4000	-2700
		% of FSR	+10000	-06750
		2's Complement HEX	7FFF	A99A
11	E Type	Engineer Unit	+10000	-02700
		% of FSR	+10000	-02700
		2's Complement HEX	7FFF	DD71
12	R Type	Engineer Unit	+17680	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
13	S Type	Engineer Unit	+17680	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
14	B Type	Engineer Unit	+18200	+00000
		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
15	N Type	Engineer Unit	+13000	-02700
		% of FSR	+10000	-02077
		2's Complement HEX	7FFF	E56B
16	C Type	Engineer Unit	+23200	+00000

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

		% of FSR	+10000	+00000
		2's Complement HEX	7FFF	0000
17	L Type	Engineer Unit	+8000	-2000
		% of FSR	+10000	-02500
		2's Complement HEX	7FFF	E000
18	M Type	Engineer Unit	+1000	-2000
		% of FSR	+05000	-10000
		2's Complement HEX	4000	8000
19	L Type DIN43710	Engineer Unit	+9000	-2000
		% of FSR	+10000	-02222
		2's Complement HEX	7FFF	E38F

i-87024W Analog Output(Only support Engineer Unit)

Type-Code	Input Range	Data Format	Max.	Min
30	0 mA to 20mA	Engineer Unit	+20000	+00000
31	4 mA to 20mA	Engineer Unit	+20000	+04000
32	0V to 10V	Engineer Unit	+10000	+00000
33	-10V to 10V	Engineer Unit	+10000	-10000
34	0V to 5V	Engineer Unit	+05000	+00000
35	-5V to 5V	Engineer Unit	+05000	-05000

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.5.2 Byte Order and Data Address

i-8K Series & i-87K Series - General Digital Input/Output


The general digital input or output module arrange its data from LSB to MSB in order (i-8040W or i-87040W).



i-87K Series - Digital Input w/ Counter

The Digital input modules in i-87K series not only provide a basic input function but also have a function of counter which maximum count can be up to 65535. You can choose that in GSD file of PROFI-8855 with the module “i-870XXW w/ Counter Func.”. The figure shows below is data arrangement of i-87040W w/ Counter.

Data Arrangement of Digital Input w/ Counter: Input Part (Slave->Master)



Data Arrangement of Digital Input w/ Counter: Output Part (Master->Slave)




Note: DO_7~DO_0 is optional, and absence at pure digital input module.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

i-8K Series & i-87K Series – General Analog Input (w/o CJC Read/Offset) and Analog Output

Analog module (without CJC function) has the I/O data of 2 byte per channel. For example, the following figure shows data arrangement of i-87024W(i-8024W).
Note: The order of input or output data is ranked by channel's identifier, so the channel with lower id value has priority over the channel with higher id.




i-8K Series & i-87K Series – General Analog Input (w/ CJC Read/Offset)

The temperature signal is a kind of analog signals. i-87K modules(i-87013W, i-87015W, i-87018W and i-87019W) provide several solutions to measure the different temperature sensors. Regardless of RTD and thermistor, it is important to note that thermocouples have the following property. The thermocouples measure the temperature difference between hot junction point and cold junction point. But the ordinary thermocouples have no cold-junction point so it can not measure the accuracy temperature using only

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

hot junction point. In order to solve this problem, i-87K modules which use thermocouple to measure temperature support the Cold Junction Compensation by an internal temperature sensor. Although CJC's problem has been dealt, there is a problem still remained. The problem is that CJC temperature sensor has some varieties compare to practical temperature. Therefore, PROFI-8855 provides an output byte to calibration this difference. The following figure is data arrangement of i-87024W w/ CJC Read/Offset.



The bytes of CJC offset have a detail description as follows. There are two kinds of data length, 2 bytes and 3 bytes. The data length with 2 byte is used in CJC without individual channel configure and the data length with 3 byte is used in CJC with individual channel configure.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Bit Arrangement of CJC-Offset using Big-Endian

Bit.	Byte0.3~0	Byte1.7	Byte1.6	Byte1.5	Byte 1.4~Byte2.0
Func.	Chn.Sel.	Ena/Disa	Reserved	Sign	Offset-Value(0.01℃)

Bit Arrangement of CJC-Offset using Little-Endian

Bit.	Byte2.3~0	Byte1.7	Byte1.6	Byte1.5	Byte 1.4~Byte0.0
Func.	Chn.Sel.	Ena/Disa	Reserved	Sign	Offset-Value

Func.	Meaning	Description
Chn.Sel.(8bits)*	Channel Selection(0~8)	CJC Calibration Channel
Ena/Disa(1bit)	Enable/Disable	CJC Calibration Enable
Reserved(1bit)	Reserved	
Sign(1bit)	Sign (0 -> Pos, 1-> Neg)	Plus or minus offset value to calibration temperature
Offset-Value (13bit)	Offset value	Offset value compare to practice temperature

*: This field is only available in i-87019RW. “Chn.Sel.” from 0 to 7 is corresponding to channel 0 to channel 7 and Chn.Sel. 8 is a broadcast channel id that available to all channel.

Note: The maximum value of Offset-Value for i-87019RW is 4096 and its unit is 0.01℃; The value for i-87108ZW is 127 and its unit is 0.1℃

Note: While Enable/Disable is set (“1”), the calibration works.

Note: The length of output data in i-87018(R)W is 2 bytes, and 3 bytes for i-87019RW and i-87018ZW.

i-8K Series & i-87K Series – Counter/Frequency

i-87082W is a counter/frequency module

There are nine input bytes in i-87082W. The last byte indicates the status of the counter, and the others are the count value of each channel. The bit arrangement of the last input byte is shown below


i-87082W – bit arrangement of the last input byte (Overflow)

Bit.	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1	Bit0
Func.	Reserved						CH1.Overflow	CH0.Overflow

The following figure shows the data arrangement of the input bytes in i-87082W module.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

i-87082W - Data arrangement of the input bytes (Cnt/Freq)



There is an additional function in i-87082W. That is “Counter Clear” command. i-87082W provide two functions. They are “Start Count” and ”Stop Count”. These functionalities increase the applicability of i-87082W module. For more detail description, please refer to the following table.

i-87082W output data (1 Byte)

Bit	7	6	5	4	3	2	1	0
Func.	E-DO.1	E-DO.0	DO.1	DO.0	C1.S1	C1.S0	C0.S1	C0.S0

Func.	Meaning	Descriptions
E-DO.1	Enable DO.1	Enable=1, DO.1 is output. Enable=0, No output.
E-DO.0	Enable DO.0	Enable=1, DO.0 is output. Enable=0, No output.
DO.1	Digital Output CH1	Digital Output value of Channel 1.
DO.0	Digital Output CH0	Digital Output value of Channel 0.
C1.S1	Channel 1 Func.Sel. 1	Channel 1 Function Selection.
C1.S0	Channel 1 Func.Sel. 0	See table below.
C0.S1	Channel 0 Func.Sel. 1	Channel 0 Function Selection.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

C0.S0	Channel 0 Func.Sel. 0	See table below.

Func.S1	Func.S0	Function
0	0	No Action(Disable)
0	1	Stop counting
1	0	Start counting
1	1	Clear count

Statistic Table of i-8K & i-87K

The following table shows the memory allocation of standard I/O and Counter / Frequency module, and we divide this table into four parts: The first table describes each function's meaning. The second table shows the input allocation of standard I/O, the third table shows the output allocation of standard I/O and the last part shows the Input/Output memory allocation of the Counter/Frequency module. We have simplified the following tables. The remainders of the table must be deduced by users.

Function Description Table

Function Name	Meaning
$D_{a\sim b}$	Digital I/O Value(bit a~b)
$A.N_{a\sim b}$	Analog Value of Channel N(bit a~b)
$C.N_{a\sim b}$	Count Value of Channel N(bit a~b)
$CJC_{a\sim b}$	CJC Temperature(bit a~b)
$Clr_{a\sim b}$	Clear Command(bit a~b)
$OvN_{a\sim b}$	Overflow Indicator(bit a~b)

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Standard I/O – input memory allocation

Meas.Type	DI		DI w/ Count		AI		AI w/ CJC.read	
Byte.Order	Big	Little	Big	Little	Big	Little	Big	Little
BYTE.0	$D_{0\sim7}$	$D_{0\sim7}$	$D_{0\sim7}$	$D_{0\sim7}$	$A.0_{8\sim15}$	$A.0_{0\sim7}$	$A.0_{8\sim15}$	$A.0_{0\sim7}$
BYTE.1	$D_{8\sim15}$	$D_{8\sim15}$	$D_{8\sim15}$	$D_{8\sim15}$	$A.0_{0\sim7}$	$A.0_{8\sim15}$	$A.0_{0\sim7}$	$A.0_{8\sim15}$
BYTE.2	$D_{16\sim23}$	$D_{16\sim23}$	$D_{16\sim23}$	$D_{16\sim23}$	$A.1_{8\sim15}$	$A.1_{0\sim7}$	$A.1_{8\sim15}$	$A.1_{0\sim7}$
BYTE.3	$D_{24\sim31}$	$D_{24\sim31}$	$D_{24\sim31}$	$D_{24\sim31}$	$A.1_{0\sim7}$	$A.1_{8\sim15}$	$A.1_{0\sim7}$	$A.1_{8\sim15}$
BYTE.4			$C.0_{8\sim15}$	$C.0_{0\sim7}$	$A.2_{8\sim15}$	$A.2_{0\sim7}$	$A.2_{8\sim15}$	$A.2_{0\sim7}$
BYTE.5			$C.0_{0\sim7}$	$C.0_{8\sim15}$	$A.2_{0\sim7}$	$A.2_{8\sim15}$	$A.2_{0\sim7}$	$A.2_{8\sim15}$
BYTE.6			$C.1_{8\sim15}$	$C.1_{0\sim7}$	$A.3_{8\sim15}$	$A.3_{0\sim7}$	$A.3_{8\sim15}$	$A.3_{0\sim7}$
BYTE.7			$C.1_{0\sim7}$	$C.1_{8\sim15}$	$A.3_{0\sim7}$	$A.3_{8\sim15}$	$A.3_{0\sim7}$	$A.3_{8\sim15}$
BYTE.8			$C.2_{8\sim15}$	$C.2_{0\sim7}$	$A.4_{8\sim15}$	$A.4_{0\sim7}$	$A.4_{8\sim15}$	$A.4_{0\sim7}$
BYTE.9			$C.2_{0\sim7}$	$C.2_{8\sim15}$	$A.4_{0\sim7}$	$A.4_{8\sim15}$	$A.4_{0\sim7}$	$A.4_{8\sim15}$
BYTE.10			$C.3_{8\sim15}$	$C.3_{0\sim7}$	$A.5_{8\sim15}$	$A.5_{0\sim7}$	$A.5_{8\sim15}$	$A.5_{0\sim7}$
BYTE.11			$C.3_{0\sim7}$	$C.3_{8\sim15}$	$A.5_{0\sim7}$	$A.5_{8\sim15}$	$A.5_{0\sim7}$	$A.5_{8\sim15}$
BYTE.12			$C.4_{8\sim15}$	$C.4_{0\sim7}$	$A.6_{8\sim15}$	$A.6_{0\sim7}$	$A.6_{8\sim15}$	$A.6_{0\sim7}$
BYTE.13			$C.4_{0\sim7}$	$C.4_{8\sim15}$	$A.6_{0\sim7}$	$A.6_{8\sim15}$	$A.6_{0\sim7}$	$A.6_{8\sim15}$
BYTE.14			$C.5_{8\sim15}$	$C.5_{0\sim7}$	$A.7_{8\sim15}$	$A.7_{0\sim7}$	$A.7_{8\sim15}$	$A.7_{0\sim7}$
BYTE.15			$C.5_{0\sim7}$	$C.5_{8\sim15}$	$A.7_{0\sim7}$	$A.7_{8\sim15}$	$A.7_{0\sim7}$	$A.7_{8\sim15}$
BYTE.16			$C.6_{8\sim15}$	$C.6_{0\sim7}$			$CJC_{8\sim15}$	$CJC_{0\sim7}$
BYTE.17			$C.6_{0\sim7}$	$C.6_{8\sim15}$			$CJC_{0\sim7}$	$CJC_{8\sim15}$

Standard I/O – output memory allocation

Meas.Type	DO		DI w/ Count		AO		AI w/ CJC.offset	
Byte.Order	Big	Little	Big	Little	Big	Little	Big	Little
BYTE.0	$D_{0\sim7}$	$D_{0\sim7}$	$clr_{24\sim31}$	$clr_{0\sim7}$	$A.0_{8\sim15}$	$A.0_{0\sim7}$	ChnSel	$offset_{7\sim0}$
BYTE.1	$D_{8\sim15}$	$D_{8\sim15}$	$clr_{16\sim23}$	$clr_{8\sim15}$	$A.0_{0\sim7}$	$A.0_{8\sim15}$	Ena& $offset_{8\sim15}$	Ena& $offset_{8\sim15}$
BYTE.2	$D_{16\sim23}$	$D_{16\sim23}$	$clr_{8\sim15}$	$clr_{16\sim23}$	$A.1_{8\sim15}$	$A.1_{0\sim7}$	$offset_{7\sim0}$	ChnSel
BYTE.3	$D_{24\sim31}$	$D_{24\sim31}$	$clr_{0\sim7}$	$clr_{24\sim31}$	$A.1_{0\sim7}$	$A.1_{8\sim15}$		
BYTE.4					$A.2_{8\sim15}$	$A.2_{0\sim7}$		
BYTE.5					$A.2_{0\sim7}$	$A.2_{8\sim15}$		
BYTE.6					$A.3_{8\sim15}$	$A.3_{0\sim7}$		
BYTE.7					$A.3_{0\sim7}$	$A.3_{8\sim15}$		
BYTE.8					$A.4_{8\sim15}$	$A.4_{0\sim7}$		
BYTE.9					$A.4_{0\sim7}$	$A.4_{8\sim15}$		
BYTE.10					$A.5_{8\sim15}$	$A.5_{0\sim7}$		
BYTE.11					$A.5_{0\sim7}$	$A.5_{8\sim15}$		


LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Counter/Frequency memory allocation


Meas.Type	i-87082W.Inp		i-87082W.Outp	
Byte.Order	Big	Little	Big	Little
BYTE.0	$C0_{24\sim31}$	$C0_{0\sim7}$	E-DO.1 /E-DO.2 /DO.1 /DO.0 /C1.S1 /C1.S0 /C0.S1 /C0.S0	E-DO.1 /E-DO.2 /DO.1 /DO.0 /C1.S1 /C1.S0 /C0.S1 /C0.S0
BYTE.1	$C0_{16\sim23}$	$C0_{8\sim15}$		
BYTE.2	$C0_{8\sim15}$	$C0_{16\sim23}$		
BYTE.3	$C0_{0\sim7}$	$C0_{24\sim31}$		
BYTE.4	$C1_{24\sim31}$	$C1_{0\sim7}$		
BYTE.5	$C1_{16\sim23}$	$C1_{8\sim15}$		
BYTE.6	$C1_{8\sim15}$	$C1_{16\sim23}$		
BYTE.7	$C1_{0\sim7}$	$C1_{24\sim31}$		
BYTE.8	$Ov0_{0\sim1}$	$Ov0_{0\sim1}$		
BYTE.9				
BYTE.10				
BYTE.11				
BYTE.12				
BYTE.13				
BYTE.14				
BYTE.15				
BYTE.16				
BYTE.17				

The following figures shown below describe the state flow of data exchange. The first figure shows the state flow of data exchange. There are four modules (i-87018ZW, i-87024W, i-87017W and i-87082W) plugged in PROFI-8855.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



The second figure shows another state flow of data exchange. There is no output module that installation in PROFI-8855 and only input module install.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.6. Diagnostic Message Report

The diagnostic messages report to DP-Master when the DP-Slave has errors or the unusual event is happened. Usually, It report diagnosis due to following standard channel-related event. Error code “2”,”3”,”5”,”6”,”7” and ”8” are supported by PROFI-8855.

Error Code	Error Type
0	Reserved
1	Short Circuit
2	Under-voltage
3	Over-voltage
4	overload
5	Over-temperature
6	Line/wire Break(Sensor Only)
7	Upper Limit Value Exceeded(Current)
8	Lower Limit Value Exceeded(Current, Sensor)
9	Error
10~15	Reserved
16~31	Manufacture Specific/Device-Related

PROFI-8855 provides diagnosis report for Analog I/O and Counter/Frequency module. In Analog I/O module, the reason of diagnosis reports is that the input/output/count exceeds the default maximum value/ minimum value or temperature sensor line break. In Counter/Frequency modules (I-87082W only), it usually due to the count exceeds the setting of “Maximum Count of Counter N” that set by Set_Prm telegram.

In PROFI-8855, the number of channel-related diagnostic message is limit to 39. The diagnostic messages large than 128 bytes (39 channel -related diagnoses) will be ignore.


The channel-related diagnosis has been described above. There is another kind of diagnosis provided by PROFI-8855; it is called device-related diagnosis. The device-related diagnosis in PROFI-8855 is “Offline-Detection”. When the module is unplugged or breakdown, PROFI-8855 will report the error with device-related diagnosis. The error-id and corresponding meaning is shown in following table.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Error ID	Meaning
1	Slot 0- Module Offline
2	Slot 1- Module Offline
4	Slot 2- Module Offline
8	Slot 3- Module Offline
16	Slot 4- Module Offline
32	Slot 5- Module Offline
64	Slot 6- Module Offline
128	Slot 7- Module Offline


Several offline modules can be detected at the same time. PROFI-8855 combines these Error-IDs into one byte and return to DP-Master once. For example, we can know that all the modules in PROFI-8855 are disconnect (offline) when DP-Master gets a device-related diagnosis with error code “255”.

There are two examples that describe different error or warning event as follows. The first example is about that the I-87082W module unplugged out of PROFI-8855 and the diagnostic message reports. The following figure can shows the report process.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


The second example is about the input value of channel 0 of I-87017W is larger than threshold value, and the diagnostic message reports. The following figure can shows the report process.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.7. Establish connection with PROFI-8855

Before establish the connection between DP-Master and PROFI-8855, user should obey the following step first.



First, users must load the electronic device description file(GSD file) of the PROFI-8855 into the DP-Master, then set the parameters of the modules plugged in PROFI-8855 respectively. Finally change your DP-master from Offline state to Operate state. While DP-Master changes to operate mode, PROFI-8855 will initial the modules. Then PROFI-8855 allocates the memory space and waits for Set_Prm telegram. The next step is waiting for Chk_Cfg telegram in order. If there is no error occurs, PROFI-8855 proceeds into data exchange state. Users can observe the status indicator LED to know the state of PROFI-8855. At the meantime, if there is any error occurs, PROFI-8855 will return to wait parameterization.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.8. Telegram cycle of data exchange

If you want to know the round-trip time of a data exchange telegram, you must know how a byte enveloped into a serial stream. In series communication, the byte transmission includes start bit, stop bit, data field and optional parity. According to the PROFIBUS specification, there is no parity bit in transmission. Therefore, one data byte will be encoded to 11 bits. Consequently, the telegram cycle time of data exchange will calculate as follow.

T = (Output data Bit Time (header include) + Station Reaction Bit Time + Input Data Bit Time (header include) + Bus Idle Bit Time + Sync-Bit Time) * Transmission Time per Bit.

Output Data Bit Time (header include) = (9 + length of output data in Byte) * 11

Station Reaction Time = Any Value that large than Min.Tsdr and smaller than Max.Tsdr

There is look up table between Baud Rate and Max.Tsdr. (This information is in GSD file)

Baud Rate(in bit per second)	Max.Tsdr (in Tbit)
9600	60
19,200	60
454,500	60
937,500	60
187,500	60
500,000	100
1,500,000	150
3,000,000	250
6,000,000	450
12,000,000	800

Input Data Bit Time (header include) = (9 + length of input data in Byte) * 11

Bus Idle Time = max **(**T_{SYN} + T_{SM} , min T_{SDR} , T_{SDI}**)**

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

For the detail, please refer to PROFIBUS Specification.

Sync. Bit Time = 33 (constant)

Transmission Time per Bit = the inverse of Baud Rate.

For example:

The data transmission time with 15 bytes output data and 30 bytes input data in 12Mbps is calculated as follows.

Parameter： T_{SYN}=33 Tbits

T_{ID1}=75 Tbits (1.5M BR)
T_{SDR}=30 Tbits (1.5M BR)
Min_Slave_Interval = 1

The time is as follows.

$T = ((9+15) * 11 + 30 + (9+30) * 11 + 33 + 75) / 12*10^6 = 69.25uS$

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


4. PROFI-8855 Guideline (Based on SyCon)

In this chapter, we make a demo with PROFI-8855 and the DP-Master of SyCon company. The demo is shown how to apply the PROFI-8855 in a realistic system.

4.1. Preprocessing


1. New a project:

Click <File->New> to establish a PROFIBUS project.



2. Import GSD file:


Click <File->CopyGSD> to copy IPDS0B85.gsd file into your SyCon.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


3. Add DP-Master to PROFIBUS network:

Adding corresponding PROFIBUS DP Master into PROFIBUS network, and modify the station address yourself.



4. Add DP-Slave to PROFIBUS network:

After copying the GSD file into SyCon, you can add “PROFI-8855” to PROFIBUS network, and modify the station address yourself.




LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5. Modify the configuration of PROFI-8855:


1. Add module(s):

Add the module(s) you want to use. In this example, we choose i-8017HW and i-8024W.



2. Modify parameter data：


Click <Parameter Data> button in right-up corner of the windows, and modify the “Common” and “Module” parameter by your preference. In this example, we use default setting.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6. Download the network configuration to DP-Master：

Click <Online->Download> to download the network setting into CIF 50-PB card.



7. Install Module(s):

In this example, we plug i-8017HW into Slot 0 and i-8024W into Slot 1.

8. Adjust the rotary switches:

In previous step, we modify the address of DP-Slave to “1”, so we must adjust the rotary switches to 01 in PROFI-8855 panel.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

9. Power supplied：


Plug the power terminator with 24VDC to PROFI-8855.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


4.2. I/O View/Modify

1. Click View->Logical Network View



2. Monitoring I/O data of Module(1):


Add the input signal of Module 1 (i-8017HW) into I/O Watch.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


3. Monitoring I/O data of Module(2):

Add the output signal of Module 2 (i-8024W) into I/O Watch.




4. Start Monitoring:

Click the right button of mouse at <Slave1>, choose Start to enable monitor.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

I/O Watch window shows a list of present state of I/O, SymName with Input00x is read-only, and SymName with Output00x is write-only.



LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5. GSD File

A GSD is a readable ASCII text file and contains both general and device-specific specifications for communication. Each of the entries describes a feature that is supported by a device. A GSD replaces the previously conventional manuals an supports automatic checks for input errors and data consistency, even during the configuration phase.

PROFI-8855 GSD file is located at ICPDAS Product CD and the following web site
http://www.icpdas.com/products/Industrial/profibus/profi-8855.htm

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000