ZT-2017 and ZT-2017C
User Manual

Warranty

All products manufactured by ICP DAS are under warranty regarding defective materials for a period of one year, beginning from the date of delivery to the original purchaser.

Warning

ICP DAS assumes no liability for any damage resulting from the use of this product. ICP DAS reserves the right to change this manual at any time without notice. The information furnished by ICP DAS is believed to be accurate and reliable. However, no responsibility is assumed by ICP DAS for its use, nor for any infringements of patents or other rights of third parties resulting from its use.

Copyright

Copyright © 2012 by ICP DAS. All rights are reserved.

Trademarks

Names are used for identification purposes only and may be registered trademarks of their respective companies.

Technical Support

If you have any problems, please feel free to contact us via email at service@icpdas.com.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Table of Contents

1 Introduction 6

1.1 Introduction to ZigBee 6

1.2 Introduction to the ZT-2000 I/O Series 7

2 Hardware Information 8

2.1 Specifications 8

2.2 Wire Connections 13

3 Setting up the ZT-2000 I/O Device 14

3.1 Introduction to the Configuration Parameters 14

3.2 Introduction to the Rotary and DIP Switches 16

3.3 Starting the ZT-2000 I/O Device 21

3.4 Communications Testing 21

3.5 Examples 23

4 Analog Input Type and Data Format 25

5 Calibration 27

6 The DCON/Modbus RTU Command Sets 29

6.1 Communicating with the ZT-2000 I/O Device 29

6.2 The DCON Protocol Command Set 29

6.2.1 Checksum 31

6.2.2 Overview of the DCON Command Set 33

6.2.3 %AANNTTCCFF 35

6.2.4 #AA 37

6.2.5 #AAN 39

6.2.6 $AA0 41

6.2.7 $AA1 43

6.2.8 $AA2 45

6.2.9 $AA5 47

6.2.10 $AA5VV 49

6.2.11 $AA6 51

6.2.12 $AA7CiRrr 53

6.2.13 $AA8Ci 55

6.2.14 $AAF 57

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.15 $AAM 58
6.2.16 $AAS1 59
6.2.17 ~** 60
6.2.18 ~AA0 61
6.2.19 ~AA1 63
6.2.20 ~AA2 65
6.2.21 ~AA3ETT 67
6.2.22 ~AAEV 69
6.2.23 ~AAO(Name) 71
6.2.24 @AACH 72
6.2.25 @AACHi 74
6.2.26 @AACHCi 76
6.2.27 @AACL 78
6.2.28 @AACLi 80
6.2.29 @AACLCi 82
6.2.30 @AADHCi 84
6.2.31 @AADI 86
6.2.32 @AADLCi 88
6.2.33 @AAHI(Data)CiT 90
6.2.34 @AALO(Data)CiT 92
6.2.35 @AARH 94
6.2.36 @AARHCi 95
6.2.37 @AARHi 97
6.2.38 @AARL 99
6.2.39 @AARLCi 100
6.2.40 @AARLi 102

6.3 Modbus RTU Protocol Command set 104
6.3.1 Modbus Address Mapping 105
6.3.2 PLC Address Mapping 108
6.3.3 01 (0x01) Reading the Coils 109
6.3.4 02 (0x02) Reading the Discrete Inputs 110
6.3.5 03 (0x03) Reading Multiple Registers 111
6.3.6 04 (0x04) Reading Multiple Input Registers 112
6.3.7 05 (0x05) Writing a Single Coil 113
6.3.8 06 (0x06) Writing Multiple Registers 114
6.3.9 15 (0x0F) Writing Multiple Coils 115
6.3.10 70 (0x46) Reading/Writing the Module Settings .. 117

7 Appendix 131

7.1 Software Configuration Mode 131

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

7.2 Dual Watchdog Operation 132
7.3 Reset Status 133
8 Troubleshooting 134

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

What's in the Shipping Package?


The shipping package contains the following items:



ZT-2000 DIO Module



ANT-124-05



Quick Start

If any of these items are missing or damaged, please contact your local distributor for more information. Save the shipping materials and cartons in case you need to ship the module in the future.

More Information

- Documentation:

  CD: \Napdos\ZigBee\ZT_Series\Document
  http://ftp.icpdas.com/pub/cd/usbcd/napdos/zigbee/zt_series/document

- Software:

  CD: \Napdos\ZigBee\ZT_Series\Utility
  http://ftp.icpdas.com/pub/cd/usbcd/napdos/zigbee/zt_series/utility

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1 Introduction

1.1 Introduction to ZigBee

ZigBee is a specification for a suite of high-level communication protocols using small, low-power digital radios based on the IEEE 802.15.4 standard for personal area networks. ZigBee devices are often used in mesh network form to transmit data over longer distances, passing data through intermediate devices to reach more distant ones. This allows ZigBee networks to be formed ad-hoc, with no centralized control or high-power transmitter/receiver able to reach all of the devices. Any ZigBee device can be tasked with running the network.

ZigBee is targeted at applications that require a low data rate, long battery life, and secure networking. ZigBee has a defined rate of 250 kbit/s, best suited for periodic or intermittent data or a single signal transmission from a sensor or input device. Applications include wireless light switches, electrical meters with in-home-displays, traffic management systems, and other consumer and industrial equipment that requires short-range wireless transfer of data at relatively low rates. The technology defined by the ZigBee specification is intended to be simpler and less expensive than other WPANs.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1.2 Introduction to the ZT-2000 I/O Series

ZT-2000 I/O series devices are small wireless ZigBee I/O modules based on the IEEE802.15.4 standard that allow data acqusition and control via personal area ZigBee networks. See Section 2.1 for more detailed information.

The ZT-2000 I/O series is a wireless data acquisition-based client/server system. Accordingly, a Net Server for the ZigBee (ZT-2570/ZT-2550) is essential in such systems. So, if there is any configuration issue of ZigBee Coordinator, please refer to the “ZT-25XX ZigBee Converter Quick Start” ducument for more information, which can be found at the following link:

http://ftp.icpdas.com/pub/cd/usbcd/napdos/zigbee/zt_series/document/

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2 Hardware Information

2.1 Specifications

ZT-2017

Analog Input	
Input Channels	8 Differential
Input Type	+/-10 V, +/-5 V, +/-1 V, +/-500 mV, +/-150 mV, +/-20 mA, 0 ~ 20 mA, 4 ~ 20 mA (Requires Optional External 125 Ω Resistor)
Resolution	16-bit
Sampling Rate	16-bit, 10 Samples/Sec. (Total)
Accuracy	+/-0.1% FSR
-3dB Bandwidth	15.7 Hz
Zero Drift	+/-20 μV/°C
Span Drift	+/-25 ppm/°C
Common Mode Rejection	86 dB
Normal Mode Rejection	100 dB
Input Impedance	>2 MΩ
Overvoltage Protection	240 Vrms
Individual Channels Configurable	Yes
Intra-module Isolated, Field-to-Logic	3000 VDC
ESD Protection	+/-4 kV Contact for each channel
LED Indicators	
ZigBee PWR	ZigBee Device Power
ZigBee Net	Zigbee Communication Indicator
Power	
Power Consumption	1.7 W (Max.)
Environment	
Operating Temperature	-25 to 75 °C
Storage Temperature	-30 to 80 ℃
Humidity	10 to 90%, Non-condensing

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Wireless	
RF Channels	16
RF Transmit Power	11 dBm
Antenna (2.4 GHz)	5 dBi Omni directional
Transmit Range (LOS)	700 m (Typical)
Max. Slaves Supported	255
EMI Certification	CE/FCC, FCC ID

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

ZT-2017C

Analog Input	
Input Channels	8 Differential
Input Type	-20 mA ~ +20 mA, 0 mA ~ +20 mA, +4 mA ~ +20 mA
Resolution	16-bit
Sampling Rate	16-bit, 10 Samples/Sec. (Total)
Accuracy	+/-0.1% FSR
-3dB Bandwidth	15.7 Hz
Zero Drift	+/-20 μV/°C
Span Drift	+/-25 ppm/°C
Common Mode Rejection	86 dB
Normal Mode Rejection	100 dB
Common Voltage	+/-200 VDC
Individual Channels Configurable	Yes
Open Wire Detection for 4 ~ 20 mA	Yes
Intra-module Isolated, Field-to-Logic	3000 VDC
ESD Protection	+/-4 kV Contact for each channel
LED Indicators	
ZigBee PWR	ZigBee Device Power
ZigBee Net	Zigbee Communication Indicator
Power	
Power Consumption	1.7 W (Max.)
Environment	
Operating Temperature	-25 to 75 °C
Storage Temperature	-30 to 80 °C
Humidity	10 to 90%, Non-condensing

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


Wireless	
RF Channels	16
RF Transmit Power	11 dBm
Antenna (2.4 GHz)	5 dBi Omni directional
Transmit Range (LOS)	700 m (Typical)
Max. Slaves Supported	255
EMI Certification	CE/FCC, FCC ID

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.


Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Pin Assignment

ZT-2017



ZT-2017C




Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.


Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2.2 Wire Connections

ZT-2017



ZT-2017C



Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3 Setting up the ZT-2000 I/O Device

3.1 Introduction to the Configuration Parameters


A. The **"ZB PID"** parameter is the group identity for a ZigBee network, and must be the same for all devices in the same ZigBee network.

B. The **"Node ID"** parameter is the individual identity of the specific ZigBee module, and must be unique for each device connected to the same ZigBee network.

C. The **"ZB Channel"** parameter indicates the radio frequency channel, and must be set to the same value as other modules on the same ZigBee network.

ZB Channel	0x00	0x01	……	0x0F
Frequency (MHz)	2405	2410	……	2480

※ *ZB channels 0x04, 0x09, 0x0E or 0x0F are recommended because they do not overlap with the Wi-Fi frequency band.*



D. Protocol/Application Mode:

When implementing custom programs based on different protocols, the following application mode(s) are recommended in order to ensure optimal performance.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000


User Program Protocol	ZT-2000	ZT-2550	ZT-2570
DCON	DCON	Transparent	Transparent
Modbus RTU	Modbus RTU	Transparent Modbus Gateway	Transparent Modbus Gateway
Modbus TCP	Modbus RTU	------	Modbus Gateway

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.2 Introduction to the Rotary and DIP Switches

The configuration of the ZT-2017/2017C can be adjusted using a combination of the external rotary switch and the DIP switches. The ZT-2000 device shoule only be rebooted once the configuration is complete.



➢ Rotary Switch

Case1: Address MSB = 0

	0	1	2	3	4	5	6	7
Address	***Note 1**	01	02	03	04	05	06	07
Node ID	***Note 1**	0x0001	0x0002	0x003	0x0004	0x0005	0x0006	0x0007
	8	9	A	B	C	D	E	F
Address	08	09	0A	0B	0C	0D	0E	0F
Node ID	0x008	0x0009	0x000A	0x000B	0x000C	0x000D	0x000E	0x000F

Case1: Address MSB = 1

	0	1	2	3	4	5	6	7

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.


Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Address	10	11	12	13	14	15	16	17
Node ID	0x0010	0x0011	0x0012	0x013	0x0014	0x0015	0x0016	0x0017
	8	9	A	B	C	D	E	F
Address	18	19	1A	0B	0C	1D	1E	1F
Node ID	0x018	0x0019	0x001A	0x001B	0x001C	0x001D	0x001E	0x001F

***Note 1: The "Address" and "Node ID" are defined via the $AANNTTCCFF command. In software configuration mode, the DIP switches for "Address", "Data Format" and "Type Code" are ignored and can also be set via the %AANNTTCCFF and $AACiRrr commands.**

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000




➢ DIP Switches

Number	Item	Status	Description
1	Address MSB	OFF	Valid Address (Node ID) from 0x01 to 0x0F
		ON	Valid Address (Node ID) from 0x10, 0x01 to 0x1F
2	Protocol	OFF	DCON Protocol
		ON	Modbus RTU Protocol
3	Checksum	OFF	Disabled (DCON Protocol)
		ON	Enabled (DCON Protocol)
4	ZB PID	OFF	ZigBee Pan ID = 0x0000
		ON	ZigBee Pan ID = 0x0001
5	ZB Channel	OFF	------
		ON	0x08
6		OFF	------
		ON	0x04
7		OFF	------
		ON	0x02
8		OFF	------
		ON	0x01
9	Data Format	OFF	Engineering Units Format
		ON	Hexadecimal Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.









LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000



➢ Type Code

DIP switches 10-12 are used to define the input type code for the ZT-2017 or ZT-2017C, as shown below.

ZT-2017









Switch Position	Type Code	Switch Position	Type Code	Switch Position	Type Code
	0x08		0x09		0x0A
	0x0B		0x0C		0x0D
	0x07		0x1A		

ZT-2017C

Switch Position	Type Code	Switch Position	Type Code	Switch Position	Type Code

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

	0x0D		0x0D		0x0D
	0x0D		0x0D		0x0D
	0x07		0x1A		

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.3 Starting the ZT-2000 I/O Device

As the ZigBee network is controlled by the ZigBee Coordinator, the ZT-2550/ZT-2570 (ZigBee Coordinator) must be configured first. Refer to the documents shown below for full details of how to configure these devices.

Once configuration of the ZigBee Coordinator has been completed, set the “Pan ID” and “RF Channel” values for the ZT-2000 I/O device to the same values as the network, and then reboot the device. The module will automatically start to function on the ZigBee network using the default protocol.

※ **Documents**

http://ftp.icpdas.com.tw/pub/cd/usbcd/napdos/zigbee/zt_series/document/zt-255x/
http://ftp.icpdas.com.tw/pub/cd/usbcd/napdos/zigbee/zt_series/document/zt-257x/

※ **Configuration Utility** (Used to configure the ZT-2000 I/O device Coordinator)

http://ftp.icpdas.com.tw/pub/cd/usbcd/napdos/zigbee/zt_series/utility/

3.4 Communications Testing

Once the ZT-2000 I/O device has joined the ZigBee network, the signal quality can be confirmed by monitoring the status of the ZigBee Net LED indicators. If the LED indicator shows a steady light, communication with the ZT-2000 I/O device has been successfully established for data acquisition and control.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

ICP DAS also provides the “DCON Utility”, which can alse be used to simulate DCON/Modbus communication. This software can be used to verify the device settings and ZigBee I/O functions.

※ The Downoad DCON Utility can be downloaded from:

http://ftp.icpdas.com/pub/cd/8000cd/napdos/driver/dcon_utility/

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.


LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

3.5 Examples


➢ Architecture Diagram



➢ Configuring the ZT-2550/ZT-2570



➢ Configuring the ZT-2000 I/O device




Number	Item	Status	Description	
1	Address MSB	OFF	Address/Node ID is **01** (Rotary Switch=1)	
2	Protocol	ON	Use the **Modbus RTU** Protocol	
3	Checksum	OFF	Disabled	
4	ZB PID	OFF	ZigBee Pan ID=**0x0000**	
5	ZB Channel	ON	0x08	ZigBee RF Channel = **0x0E**
6		ON	0x04	
7		ON	0x02	
8		OFF	------	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

➢ Simulating I/O channel operation via the DCON Utility

1. Launch the DCON Utility and select the appropriate COM Port settings to connect to the ZigBee Coordinator (ZT-2550/ZT-2570).
2. Click the “Search” button to start searching for ZT-2000 I/O devices connected to the same ZigBee network.
3. If any ZT-2000 I/O devices are found, they will be displayed in the device list windows. Double-click the name of the name of the module to start operating platform.



Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4 Analog Input Type and Data Format

Type Code	Input Type	Data Format	+F.S.	-F.S.
07	+4 to +20 mA	Engineering Units	+20.000	+04.000
		% of FSR*2	+100.00	+000.00
		2's Comp. Hex	FFFF	0000
08*1	-10 to +10 V	Engineering Units	+10.000	-10.000
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
09*1	-5 to +5 V	Engineering Units	+5.0000	-5.0000
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
0A*1	-1 to +1 V	Engineering Units	+1.0000	-1.0000
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
0B*1	-500 to +500 mV	Engineering Units	+500.00	-500.00
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
0C*1	-150 to +150 mV	Engineering Units	+150.000	-150.00
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
0D	-20 to +20 mA	Engineering Units	+20.000	-20.000
		% of FSR*2	+100.00	-100.00
		2's Comp. Hex	7FFF	8000
1A	0 to +20 mA	Engineering Units	+20.000	+00.000
		% of FSR*2	+100.00	+000.00
		2's Comp. Hex	FFFF	0000
*1: Only available on the ZT-2017 *2: FSR (Full Scale Range)				

➢ Analog Input Over/Under Range Readings

	Over Range	Under Range
Engineering Units	+9999.9	-9999.9
% of FSR	+999.99	-999.99

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2's Complement Hex	7FFF	8000

- Analog Input Over/Under Range Readings when using the Modbus RTU protocol

Over Range	Under Range
7FFFh	8000h

- Data Format Settings (FF)

7	6	5	4	3	2	1	0
FS	Reserved					DF	

Key	Description
DF	Data Format 00: Engineering Units 01: % of FSR 10: 2's Complement Hexadecimal
FS	Filter Settings 0: 60 Hz Rejection 1: 50 Hz Rejection.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5 Calibration

➢ Warning

Performing calibration is not recommended until the process is fully understood.

The calibration procedure is as follows:

1. Warm up the module for at least 30 minutes.
2. Set the type code to the type you wish to calibrate. Refer to Sections 1.8 and 2.10 for details.
3. Enable calibration. Refer to Section 2.20 for details.
4. Apply the zero calibration voltage/current.
5. Send the zero calibration command. Refer to Section 2.5 for details.
6. Apply the span calibration voltage/current.
7. Send the span calibration command. Refer to Section 2.4 for details.
8. Repeat steps 3 to 7 three times.

➢ Notes

1. Connect the calibration voltage/current source to channel 0.
2. Calibration voltages and currents are shown below.
3. Switch to DCON protocol mode before calibrating the module. Refer to Section 1.5 for details of how to switch protocols.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

➢ Calibration Voltage Type used by the ZT-2017 and ZT-2017C

Type Code	08*1	09*1	0A*1	0B*1	0C*1	0D
Zero Input	0 V	0 V	0 V	0 mV	0 mV	0 mA
Span Input	+10 V	+5 V	+1 V	+500 mV	+150 mV	+20 mA
*1: Only available on the ZT-2017						

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6 The DCON/Modbus RTU Command Sets

6.1 Communicating with the ZT-2000 I/O Device

ICP DAS ZT-2000 I/O devices can operate using both the DCON and the Modbus RTU protocol. Adjust the DIP switch number 2 to select the DCON or Modbus RTU protocol and reboot the ZT-2000 I/O device to correct protocol.

6.2 The DCON Protocol Command Set

All ZT-2000 I/O series devices are controlled via wireless broadcast commands, so each device must have a unique address that is saved in the EEPROM of the device to denote the difference.

Consequently, all command and response formats contain the destination address of the module. When an I/O device receives a command, it will determine whether or not to respond based on the address contained in the command. However, there are two exceptions, #** and ~** commands.

- DCON Command Format

Delimit Character	Module Address	Command	[CHECKSUM]	CR

- DCON Response Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Delimit Character	Module Address	Data	[CHECKSUM]	CR

※ Note: ‘CR’ is the end of command (carriage return) character used to end a frame.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.1 Checksum

Calulating the Checksum:

Sum the ASCII codes of all the characters contained in the command in addition to the 'CR' terminator. The Checksum is the sum value expressed in Hexadecimal format.

Example: Command "$012(CR)"

Sum = '$' + '0' + '1' + '2' = 24h + 30h + 31h + 32h = B7h

Checksum = "B7"

DCON Command with Checksum ="$012B7(CR)"

Example: Response "!01200600(CR)"

Sum = '!' + '0' + '1' + '2' + '0' + '0' + '6' + '0' + '0'

= 21h+30h+31h+32h+30h+30h+36h+30h+30h

= 1AAh

Checksum = "AA"

DCON Response with Checksum = "!01200600AA(CR)"

Note: The Checksum is the sum value expressed in capital letters.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.2 Overview of the DCON Command Set

General Command Set			
Command	**Response**	**Description**	**Section**
%AANNTTCCFF	!AA	Sets the Module Configuration	6.2.3
#AA	>(Data)	Reads Data from the Analog Inputs	6.2.4
#AAN	>(Data)	Reads Data from the Analog Input of a Channel	6.2.5
$AA0	!AA	Performs a Span Calibration	6.2.6
$AA1	!AA	Performs a Zero Calibration	6.2.7
$AA2	!AANNTTCCFF	Reads the Module Configuration	6.2.8
$AA5	!AAS	Reads the Reset Status of the Module	6.2.9
$AA5VV	!AA	Enables/Disables each Channel	6.2.10
$AA6	!AAVV	Reads the Enabled/Disabled Status of each Channel	6.2.11
$AA7CiRrr	!AA	Sets the Type Code of a Channel	6.2.12
$AA8Ci	!AACiRrr	Reads the Type Code of a Channel	6.2.13
$AAF	!AA(Data)	Reads the Firmware Version of the Modeule	6.2.14
$AAM	!AA(Data)	Reads the Name of the Module	6.2.15
$AAS1	!AA	Reloads the Default Calibration Parameters	6.2.16
~AAEV	!AA	Enables/Disables Calibration	6.2.22
~AAO(Name)	!AA	Sets the Name of the Module	6.2.23
@AACH	!AA	Clears the High Latch Values for all Channels	6.2.24
@AACHi	!AA	Clears the High Latch Value for a Specific Channel	6.2.25
@AACHCi	!AA	Clears the High Latched Alarm for a Specific Channel	6.2.26
@AACL	!AA	Clears the Low Latch Values for all Channels	6.2.27
@AACLi	!AA	Clears the Low Latch Value for a Specific Channel	6.2.28
@AACLCi	!AA	Clears the Low Latched Alarm for a Specific Channel	6.2.29

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

@AADHCi	!AA	Disables the High Alarm for a Specific Channel	6.2.30
@AADI	!AAHHLL	Reads the Status of the Alarms for all Channels	6.2.31
@AADLCi	!AA	Disables the Low Alarm for a Specific Channel	6.2.32
@AAHI(Data)CiT	!AA	Sets the the High Alarm Value for a Specific Channel	6.2.33
@AALO(Data)CiT	!AA	Sets the Low Alarm Value for a Specific Channel	6.2.34
@AARH	!AA(Data)	Reads the High Latch Values for all Channels	6.2.35
@AARHCi	!AA(Data)S	Reads the High Alarm Value for a Specific Channel	6.2.36
@AARHi	!AA(Data)	Reads the High Latch Value for a Specific Channel	6.2.37
@AARL	!AA(Data)	Reads the Low Latch Values for all Channels	6.2.38
@AARLCi	!AA(Data)S	Reads the Low Alarm Value for a Specific Channel	6.2.39
@AARLi	!AA(Data)	Reads the Low Latch Value for a Specific Channel	6.2.40
Host Watchdog Command Sets			
Command	**Response**	**Description**	**Section**
~**	No Response	Host OK Command	6.2.17
~AA0	!AASS	Reads the Status of the Host Watchdog	6.2.18
~AA1	!AA	Resets the Host Watchdog Timeout Status	6.2.19
~AA2	!AAETT	Reads the Timeout Settings for the Host Watchdog	6.2.20
~AA3ETT	!AA	Sets the Host Watchdog Timeout Settings	6.2.21

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.3 %AANNTTCCFF

Description
This command is used to set the configuration of a specific module.

Syntax	
%AANNTTCCFF[CHECKSUM](CR)	
%	Delimiter character
AA	The address of the module to be configured in hexadecimal format (00 to FF)
NN	The new address of the module in hexadecimal format (00 to FF)
TT	00 (Reserved)
CC	0A (Reserved)
FF	The command used to set the data format, checksum, and filter settings (See Section 4 for details)

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	%0320000A80
Response	!03
In Normal mode, the address 0x20 is saved to the EEPROM and the data format for module 03 is set to 80 (50 Hz rejection). The module returns a response indicating that the command was successful.	
Command	%0320000A80
Response	!20
In Software Configuration mode, the address 0x20 is saved to the EEPROM and	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

the data format for module 03 is set to 80 (50 Hz rejection). The module returns a response indicating that the command was successful.	
Command	%0303000000
Response	?03
Attempts to set the configuration for module 03 and returns a response indicating that an error occurred is returned because the “CC”parameter have to be 0A.	

※Related Commands: $AA2

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.4 #AA

Description
This command is used to read the data from all the analog input channels of a specified module.

Syntax	
#AA[CHECKSUM](CR)	
#	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)

Response	
Valid Command	>(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
>	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
(Data)	The data from all the analog input channels, see Section 4 for details of the data format. Data from disabled channels is filled with space characters.
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	#03
Response	>+10.000+10.000+10.000+10.000+10.000+10.000+10.000+10.000
Reads the analog input channels of module 03 and returns a response indicating that the command was successful, with the data for all analog input channels in engineering format.	

※Related Commands: %AANNTTCCFF, $AA2, $AA7CiRrr

※Related Topics: Section 4 Analog Input Type and Data Format.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Section 7.1 Software Configuration Mode

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.5 #AAN

Description
This command is used to read the analog input data from a specific channel of a specified module.

Syntax	
#AAN[CHECKSUM](CR)	
#	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
N	The channel to be read, zero based

Response	
Valid Command	>(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
>	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command. Note that a response indicating that the command was successful will be returned if the specified channel is incorrect.
(Data)	The analog input data from the specified channel. See Section 4 for details of the data format. If the specified channel is disabled, then the data field will be filled with space characters.
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	#032
Response	>+025.13
Reads data from channel 2 of module 03 and returns a response indicating that the command was successful, and the analog input value is +025.13mV.	
Command	#039
Response	?03
Attempts to read data from channel 9 of module 03. A response indicating that	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

an error occurred is returned because channel 9 does not exist.

※Related Commands: %AANNTTCCFF, $AA2, $AA7CiRrr

※Related Topics: Section 4 Analog Input Type and Data Format.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.6 $AA0

Description
This command is used to perform a span calibration on a specified module.

Syntax	
$AA0[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be calibrated in hexadecimal format (00 to FF)
0	The command to perform the span calibration

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command.
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$030
Response	?03
Attempts to perform a span calibration on module 03, but a response indicating that the command was unsuccessful is returned because the “Enable Calibration” command (~AAEV, see Section 6.2.22) was not sent in advance.	
Command	~03E1
Response	!03
Enables calibration on module 03 and returns a response indicating that the command was successful.	
Command	$030
Response	!03
Performs a span calibration on module 03 and returns a response indicating that	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

the command was successful.

※Related Commands: $AA1, ~AAEV

※Related Topics: Section 5 Calibration

※Notes: The “Enable Calibration” command, ~AAEV, and the “Zero Calibration” command, $AA1, must be sent before this command is used. See Sections 6.2.22 and 6.2.7 for details.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.7 $AA1

Description
This command is used to perform a zero calibration on a specified module.

Syntax	
$AA1[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be calibrated in hexadecimal format (00 to FF)
1	The command to perform the zero calibration

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$031
Response	?03
Attempts to perform a zero calibration on module 03, but a response indicating that the command was unsuccessful is returned because the “Enable Calibration” command (~AAEV, see Section 6.2.22) was not sent in advance.	
Command	~03E1
Response	!03
Enables calibration on module 03 and returns a response indicating that the command was successful.	
Command	$031
Response	!03
Performs a zero calibration on module 03 and returns a response indicating that the command was successful.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: $AA0, ~AAEV

※Related Topics: Section 5 Calibration

※Notes:

1. The “Enable Calibration” command, ~AAEV, must be sent before this command is used. See Section 6.2.22 for details.
2. This command must be sent before the “Span Calibration” command, $AA0, is used. See Section 6.2.6 for details.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.8 $AA2

Description
This command is used to read the configuration of a specified module.

Syntax	
$AA2[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
2	The command to read the configuration of the module

Response	
Valid Command	!NNTTCCFF[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
NN	The address of the module that is saved in the EEPROM in hexadecimal format (00 to FF)
TT	00 (Reserved)
CC	0A (Reserved)
FF	The data format, checksum settings and filter settings for the module. See Section 4 for details.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$032
Response	!FF000A00
In Normal mode, reads the configuration of module 03. The response indicating that the command was successful and shows that the address stored in the EEPROM is 0xFF, 60 Hz rejection and engineering units format.	
Command	$FF2
Response	!FF000A00
In Software Configuration mode, reads the configuration of module FF. The response indicating that the command was successful and shows that the	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

address stored in the EEPROM is 0xFF, 60 Hz rejection and engineering units format.

※Related Commands: %AANNTTCCFF

※Related Topics: Section 4 Analog Input Type and Data Format
Section 7.1 Software Configuration Mode

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.9 $AA5

Description
This command is used to read the reset status of a specified module.

Syntax	
$AA5[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
5	The command to read the reset status of the module

Response	
Valid Command	!AAS[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
S	The reset status of the module: 0: This is not the first time the command has been sent since the module was powered on, which denotes that there has been no module reset since the last $AA5 command was sent. 1: This is the first time the command has been sent since the module was powered on.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$035
Response	!031
Reads the reset status of module 03. The module returns a response indicating that the command was successful and that it is a first time the $AA5 command has been sent since the module was powered on.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Command	$035
Response	!030
Reads the reset status of module 03. The module returns a response indicating that the command was successful and that there has been no module reset since the last $AA5 command was sent.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.10 $AA5VV

Description
This command is used to specify the channels to be enabled on a specified module.

Syntax	
$AA5VV[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be set in hexadecimal format (00 to FF)
5	The command to set the channels to enabled
VV	A two-digit hexadecimal value, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that the channel is disabled, and 1 denotes that the channel is enabled.

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command. Note that a response indicating that the command was invalid will be returned if an attempt is made to enable a channel that is not present.
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$0353A
Response	!03
Enables channels 1, 3, 4, and 5 on module 03 and disables all other channels. The module returns a response indicating that the command was successful.	
Command	$036
Response	!033A
Reads the status of the channels of module 03, and returns a response indicating that the command was successful , with a value of 3A, which denotes that	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

channels 1, 3, 4, and 5 are enabled and all other channels are disabled.

※Related Commands: $AA6

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.11 $AA6

Description
This command is used to read the enabled/disabled status of each channel of a specified module.

Syntax	
$AA6[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecfimal format (00 to FF)
6	The command to read the status of the channel

Response	
Valid Command	!AAVV[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
VV	A two-digit hexadecimal value, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that the channel is disabled, and 1 denotes that the channel is enabled.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$0353A
Response	!03
Enables channels 1, 3, 4, and 5 and disables all other channels on module 03. The module returns a response indicating that the command was successful.	
Command	$036
Response	!033A
Reads the status all of the channels of module 03, and returns a response indicating that the command was successful with a value of 3A, which denotes that channels 1, 3, 4, and 5 are enabled and all other channels are disabled.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: $AA5VV

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.12 $AA7CiRrr

Description
This command is used to set the type code of a specific channel on a specified module.

Syntax	
$AA7CiRrr[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be set in hexadecimal format (00 to FF)
7	The command to set the channel range code
Ci	i specifies the input channel to be set (0-7)
Rrr	rr represents the type code of the channel to be set. See Section 4 for details.

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	$037C0R08
Response	!03
Sets the type code for channel 0 of module 03 to 8 (-10 ~ +10V), and the module returns a response indicating that the command was successful.	
Command	$037C5R09
Response	!03
Sets the type code for channel 5 of module 03 to 9 (-5 ~ +5V), and the module returns a response indicating that the command was successful.	
Command	$037C1R80
Response	?03

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Attempts to set the type code for channel 1 of module 03 to 80. The module returns a response indicating that the command was unsuccessful because the type code is incorrect.

※Related Commands: $AA8Ci

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.13 $AA8Ci

Description
This command is used to read the type code information for a specific channel on a specified module.

Syntax	
$AA8Ci[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
8	The command to read the type code of the channel
Ci	Specifies which channel to access for the type code information (0-7)

Response	
Valid Command	!AACiRrr[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
Ci	i specifies which input channel the type code information relates to.
Rrr	rr represents the type code of the specified input channel. See Section 4 for details.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	$038C0
Response	!03C0R08
Reads the Type Code for channel 0 of module 03 and returns a response indicating that the command was successful, with a value of 8 (-10 ~ +10V).	
Command	$038C9
Response	?03
Attempts to read the type code for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: $AA7CiRrr

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.14 $AAF

Description
This command is used to read the firmware version of a specified module.

Syntax	
$AAF[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
F	The command to read the firmware version of the module

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The firmware version of the module as a string value
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	$03F
Response	!03A1.0
Reads the firmware version of module 03, and returns a response indicating that the command was successful and showing that firmware is version A1.0.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.15 $AAM

Description
This command is used to read the name of a specified module.

Syntax	
$AAM[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
M	The command to read the name of the module

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The name of the module as a string value
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	$03M
Response	!03ZT-2017
Reads the name of module 03 and returns a response indicating that the command was successful, and that the name of the module is “ZT-2017”.	

※Related Commands: ~AAO(Name)

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.16 $AAS1

Description
This command is used to reload the factory default calibration parameters for a specified module, including the internal calibration parameters.

Syntax	
$AAS1[CHECKSUM](CR)	
$	Delimiter character
AA	The address of the module where the default parameters are to be reloaded in hexadecimal format (00 to FF)
S1	The command to reload the factory default calibration parameters

Response	
Valid Command	!AA [CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	$03S1
Response	!03
Sends a command to reload the factory default calibration parameters for module 03 and returns a response indicating that the command was successful.	

※Related Commands: ~AAEV, $AA0, $AA1

※Related Topics: Section 5 Calibration

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.17 ~**

Description
This command is used to inform all modules that the Host is OK.

Syntax	
~**[CHECKSUM](CR)	
~	Delimiter character
**	The “Host OK” command

Response
There is no response to this command.

Example	
Command	~**
Response	No response
Sends a “Host OK” command to all modules.	

※Related Commands: ~AA0, ~AA1, ~AA2, ~AA3ETT

※Related Topics: Section 7.2 Dual Watchdog Operation.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.18 ~AA0

Description
This command is used to read the status of the Host Watchdog for a specified module.

Syntax	
~AA0CHKSUM](CR)	
~	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
0	The command to read the status of the Host Watchdog

Response	
Valid Command	!AASS[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
SS	Two hexadecimal digits that represent the status of the Host Watchdog, where: Bit 2: 0 indicates that no Host Watchdog timeout has occurred, and 1 indicates that a Host Watchdog timeout has occurred. Bit 7: 0 indicates that the Host Watchdog is disabled, and 1 indicates that the Host Watchdog is enabled, The status of the Host Watchdog is stored in EEPROM, and can only be reset by using the ~AA1 command.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Command	~030
Response	!0300
Reads the status of the Host Watchdog for module 03 and returns a response indicating that the command was successful, with a value of 00, meaning that the Host Watchdog is disabled and no Host Watchdog timeout has occurred.	
Command	~030
Response	!0304
Reads the status of the Host Watchdog for module 03 and returns a response indicating that the command was successful, with a value of 04, meaning that a Host Watchdog timeout has occurred.	

※Related Commands: ~**, ~AA1, ~AA2, ~AA3ETT

※Related Topics: Section 7.2 Dual Watchdog Operation

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.19 ~AA1

Description
This command is used to reset the status of the Host Watchdog timeout for a specified module.

Syntax	
~AA1[CHECKSUM](CR)	
~	Delimiter character
AA	The address of the module to be reset in hexadecimal format (00 to FF)
1	The command to reset the status of the Host Watchdog timeout

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	~030
Response	!0304
Reads the status of the Host Watchdog for module 03 and returns a response indicating that the command was successful, and that a Host Watchdog timeout has occurred.	
Command	~031
Response	!03
Resets the status of the Host Watchdog timeout for module 03 and returns a response indicating that the command was successful.	
Command	~030
Response	!0300
Reads the status of the Host Watchdog for module 03 and returns a response	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

indicating that the command was successful, showing that no Host Watchdog timeout has occurred.

※Related Commands: ~**, ~AA0, ~AA2, ~AA3ETT

※Related Topics: Section 7.2 Dual Watchdog Operation

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.20 ~AA2

Description
This command is used to read the Host Watchdog timeout value for a specified module.

Syntax	
~AA2[CHECKSUM](CR)	
~	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
2	The command to read the Host Watchdog timeout value

Response	
Valid Command	!AAEVV[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
E	The status of the Host Watchdog 0: The Host Watchdog is disabled 1: The Host Watchdog is enabled
VV	Two hexadecimal digits to represent the timeout value in tenths of a second. For example, 01 denotes 0.1 seconds and FF denotes 25.5 seconds.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	~032
Response	!031FF
Reads the Host Watchdog timeout value for module 03 and returns a response indicating that the command was successful, with a value of 1FF, which denotes that the Host Watchdog is enabled and the Host Watchdog timeout value is 25.5 seconds.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: ~**, ~AA0, ~AA1, ~AA3ETT

※Related Topics: Section 7.2 Dual Watchdog Operation

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.21 ~AA3ETT

Description
This command is used to enable/disable the Host Watchdog for a specified module, and sets the Host Watchdog timeout value.

Syntax	
~AA3ETT[CHECKSUM](CR)	
~	Delimiter character
AA	The address of the module to be configured in hexadecimal format (00 to FF)
3	The command to enable or disable the Host Watchdog
E	The command to set the Host Watchdog: 0: Disables the Host Watchdog 1: Enables the Host Watchdog
TT	Two hexadecimal digits to represent the Host Watchdog timeout value in tenths of a second. For example, 01 denotes 0.1 seconds and FF denotes 25.5 seconds.

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	~033164
Response	!01
Enables the Host Watchdog for module 03 and sets the Host Watchdog timeout value to 10.0 seconds. The module returns a response indicating that the command was successful.	
Command	~032

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Response	!01164
Reads the Host Watchdog timeout value for module 03. The module returns a response indicating that the command was successful, with a value of 164, which denotes that the Host Watchdog is enabled and that the Host Watchdog timeout value is 10.0 seconds.	

※Related Commands: ~**, ~AA0, ~AA1, ~AA2

※Related Topics: Section 7.2 Dual Watchdog Operation

※Note: When a Host Watchdog timeout occurs, the Host Watchdog is disabled. The ~AA3ETT command should be sent again to re-enable the Host Watchdog.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.22 ~AAEV

Description
This command is used to enable/disable calibration of a specified module.

Syntax	
~AAEV[CHECKSUM](CR)	
~	Delimiter character
AA	The address of the module where calibration is to be enabled/disabled in hexadecimal format (00 to FF)
E	The command to enable/disable calibration
V	The command to 0: Disables calibration 1: Enables calibration

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	$030
Response	?03
Attempts to send a command to perform a span calibration on module 03, and returns a response indicating that the command was unsuccessful because the “Enable Calibration” command (~AAEV) has not yet been sent.	
Command	~03E1
Response	!03
Enables calibration on module 03 and returns a response indicating that the command was successful.	
Command	$030

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Response	!03
Sends a command to perform a span calibration on module 03 and returns a response indicating that the command was successful.	

※Related Commands: $AA0, $AA1, $AAS1

※Related Topics: 5 Calibration

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.23 ~AAO(Name)

Description
This command is used to set the name of a specified module.

Syntax	
~AAO(Name)[CHECKSUM](CR)	
~	Delimiter character
AA	The address of the module to be set in hexadecimal format (00 to FF)
O	The command to set the name of the module
(Name)	The new name of the module (Max. 8 characters)

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	~03OZT-2017
Response	!03
Sets the name of module 03 to “ZT-2017” and returns a response indicating that the command was successful.	
Command	$03M
Response	!03ZT-2017
Reads the name of module 03 and returns a response indicating that the command was successful, with the name “ZT-2017”.	

※Related Commands: $AAM

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.24 @AACH

Description
This command is used to clear the high latch value for all channels of a specified module.

Syntax	
@AACH[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CH	The command to clear the high latch values

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03RH0
Response	!03+05.000
Reads the high latch values for channel 0 of module 03 and returns a response indicating that the command successful, with a value of +05.000.	
Command	@03CH
Response	!03
Clears the high latch values for module 03 and returns a response indicating that the command was successful.	
Command	@03RH0
Response	!03+00.000
Reads the high latch value for channel 0 of module 03 and returns a response indicating that the command was successful, with a value of +00.000 denoting	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

that the high latch value has been cleared.

※Related Commands: @AACHi, @AARH, @AARHi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.25 @AACHi

Description
This command is used to clear the high latch value for a specific channel of a specified module.

Syntax	
@AACHi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CH	The command to clear the high latch value
i	The channel to be cleared, zero based

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03RH1
Response	!03+06.000
Reads the high latch value for channel 1 of module 03 and returns a response indicating that the command was successful, with a value of +06.000.	
Command	@03CH1
Response	!03
Clears the high latch value for channel 1 of module 03 and returns a response indicating that the command was successful.	
Command	@03RH1
Response	!03+00.000
Reads the high latch value for channel 1 of module 03 and returns a response	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

indicating that the command was successful, with a value of +00.000 denoting that the high latch value has been cleared.	
Command	@03CH9
Response	?03
Attempts to clear the high latch value for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

※Related Commands: @AACH, @AARH, @AARHi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.26 @AACHCi

Description
This command is used to clear the status of the high alarm for a specific channel of a specified module.

Syntax	
@AACHCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CHC	The command to clear the status of the high alarm
i	The channel to be cleared, zero based

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03DI
Response	!038000
Reads the current status of the alarm for module 03 and returns a response indicating that the command was successful, and that a high alarm has occurred on channel 7.	
Command	@03CHC7
Response	!03
Clears the status of the high alarm for channel 7 of module 03 and returns a response indicating that the command was successful.	
Command	@03DI
Response	!030000

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Reads the current status of the alarms for module 03 and returns a response indicating that the command was successful, and that no alarms have occurred.	
Command	@03CHC9
Response	?03
Attempts to clear the status of the high alarm for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

※Related Commands: @AACH, @AARH, @AARHi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.27 @AACL

Description
This command is used to clear the low latch value for all channels of a specified module.

Syntax	
@AACL[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CL	The command to clear the low latch values

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03RL0
Response	!03-05.000
Reads the low latch value for channel 0 of module 03 and returns a response indicating that the command was successful, with a value of -05.000.	
Command	@03CL
Response	!03
Clears the low latch values for module 03 and returns a response indicating that the command was successful.	
Command	@03RL0
Response	!03+00.000
Reads the low latch value for channel 0 of module 03 and returns a response indicating that the command was successful, with a value of +00.000 denoting	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

that all low latch values have been cleared.

※Related Commands: @AACLi, @AARL, @AARLi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.28 @AACLi

Description
This command is used to clear the low latch value for a specific channel of a specified module.

Syntax	
@AACLi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CL	The command to clear the low latch value
i	The channel to be cleared, zero based

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03RL1
Response	!03-06.000
Reads the low latch value for channel 1 of module 03 and returns a response indicating that the command was successful, with a value of -06.000.	
Command	@03CL1
Response	!03
Clears the low latch value for channel 1 of module 03 and returns a response indicating that the command was successful.	
Command	@03RL1
Response	!03+00.000
Reads the low latch value for channel 1 of module 03 and returns a response	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

indication that the command was successful, with a value of +00.000 denoting that the low latch value has been cleared.	
Command	@03CL9
Response	?03
Attempts to clear the low latch value for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

※Related Commands: @AACL, @AARL, @AARLi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.29 @AACLCi

Description
This command is used to clear the status of the low alarm for a specific channel of a specified module.

Syntax	
@AACLCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be cleared in hexadecimal format (00 to FF)
CLC	The command to clear the status of the low alarm
i	The channel to be cleared, zero based

Response	
Valid Command	!AA [CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03DI
Response	!030080
Reads the current status of the alarms for module 03 and returns a response indicating that the command was successful, and that a low alarm has occurred on channel 7.	
Command	@03CLC7
Response	!03
Clears the status of the low alarm for channel 7 of module 03 and returns a response indicating that the command was successful.	
Command	@03DI
Response	!030000

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Reads the current status of the alarms for module 03 and returns a response indicating that the command was successful, and that no alarms has occurred.	
Command	@03CLC9
Response	?03
Attempts to clear the status of the low alarm for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

※Related Commands: @AACL, @AARL, @AARLi

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.30 @AADHCi

Description
This command is used to disable the high alarm for a specific channel of a specified module.

Syntax	
@AADHCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be configured in hexadecimal format (00 to FF)
DH	The command to disable the high alarm
Ci	The channel where the alarm is to be disabled, zero based

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03DHC0
Response	!03
Disables the high alarm for channel 0 of module 03 and returns a response indicating that the command was successful.	
Command	@03DI
Response	!03FEFF
Reads the status of the alarms for module 03 and returns a response indicating that the command was successful, and that the high alarm for channel 0 is disabled and all others are enabled.	
Command	@03DHC9
Response	?03

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Attempts to disable the high alarm for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.

※Related Commands: @AADI

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.31 @AADI

Description
This command is used to read the status of the alarms for a specified module.

Syntax	
@AADI[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
DI	The command to read the status of the alarms

Response	
Valid Command	!AAHHLL[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
HH	A two-digit hexadecimal value, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that a high alarm has not occurred, and 1 denotes that a high alarm has occurred.
LL	A two-digit hexadecimal value, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that a low alarm has not occurred, and 1 denotes that a low alarm has occurred.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03DI
Response	!034008
Reads the status of the alarms for module 03 and returns a response indicating that the command was successful, and that a high alarm has occurred on channel 6 and a low alarm has occurred on channel 3.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

LRI Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: @AADHCi, @AADLCi, @AAHI(Data)CiT, @AALO(Data)CiT

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.32 @AADLCi

Description
This command is used to disable the low alarm for a specific channel of a specified module.

Syntax	
@AADLCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be configured in hexadecimal format (00 to FF)
DL	The command to disable the low alarm
Ci	The channel where the alarm is to be disabled, zero based

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03DLC5
Response	!03
Disables the low alarm for channel 5 of module 03 and returns a response indicating that the command was successful.	
Command	@03DI
Response	!03FFDF
Reads the status of the alarms for module 03 and returns a response indicating that the command was successful, and that the low alarm for channel 5 is disabled and all others are enabled.	
Command	@03DLC9
Response	?03

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Attempts to disable the low alarm for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.

※Related Commands: @AADI

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.33 @AAHI(Data)CiT

Description
This command is used to set the high alarm for a specific channel of a specified module.

Syntax	
@AAHI(Data)CiT[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be set in hexadecimal format (00 to FF)
HI	The command to set the high alarm
(Data)	The high alarm limit, which should be consistent with the engineering units format. Refer to Section 4 for details.
Ci	The channel to be set, zero based
T	The alarm type: M: Momentary Alarm L: Latched Alarm

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03HI+09.000C0M
Response	!03
Sets the high alarm limit for channel 0 of module 03 to +09.000 and sets the alarm type to momentary, and returns a response indicating that the command was successful.	
Command	@03RHC0

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Response	!03+09.0001
Reads the status of the alarms for channel 0 of module 03 and returns a response indicating that the command was successful, and that the high alarm limit is +09.000 and the alarm type is momentary.	

※Related Commands: @AARHCi, @AADHCi, @AADI

※Related Topics: Section 4 Analog Input Type and Data Formart

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.34 @AALO(Data)CiT

Description
This command is used to set the low alarm for a specific channel of a specified module.

Syntax	
@AALO(Data)CiT[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be set in hexadecimal format (00 to FF)
LO	The command to set the low alarm
(Data)	The low alarm limit, which should be consistent with the engineering units format. Refer to Section 4 for details.
Ci	The channel to be set, zero based
T	The alarm type: M: Momentary Alarm L: Latched Alarm

Response	
Valid Command	!AA[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Examples	
Command	@03LO-03.000C1L
Response	!03
Sets the low alarm limit for channel 1 of module 03 to -03.000 and sets the alarm type to latched, and returns a response indicating that the command was successful.	
Command	@03RLC1

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Response	!03-03.0002
Reads the status of the alarms for channel 1 of module 03 and returns a response indicating that the command was successful, and that the low alarm limit is -03.000 and the alarm type is latched.	

※Related Commands: @AARLCi, @AADCi, @AADI

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.35 @AARH

Description
This command is used to read the high latch values for all channels of a specified module.

Syntax	
@AARH[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RH	The command to read the high latch values

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The high latch values for all channels. See Section 4 for details of the data format.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03RH
Response	!03+08.000+00.000+00.000+00.000+00.000+00.000+00.000+00.000
Reads the high latch values for module 03 and returns a response indicating that the command was successful, with the data in engineering units format.	

※Related Commands: @AACH, @AACHi, @AARHi

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.36 @AARHCi

Description
This command is used to read the status of the high alarm for a specific channel of a specified module.

Syntax	
@AARHCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RH	The command to read the status of the high alarm
Ci	The channel to be read, zero based

Response	
Valid Command	!AA(Data)S[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The high latch values for all channels. See Section 4 for details of the engineering units format.
S	The alarm type: 0: Alarm Disabled 1: Momentary Alarm 2: Latched Alarm
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03HI+09.000C0M
Response	!03
Sets the high alarm limit for channel 0 of module 03 to +09.000 and sets the alarm type to momentary, and returns a response indicating that the command	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

was successful.	
Command	@03RHC0
Response	!03+09.0001
Reads the status of the alarms for channel 0 of module 03 and returns a response indicating that the command was successful, and that the high alarm limit is +09.000 and the alarm type is momentary.	

※Related Commands: @AAHI(Data)CiT, @AADHCi, @AADI

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.37 @AARHi

Description
This command is used to read the high latch value for a specific channel of a specified module.

Syntax	
@AARHCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RH	The command to read the high latch value
i	The channel to be read, zero based

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The high latch value for the specific channel. See Section 4 for details of the data format.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03RH0
Response	!03+08.000
Reads the high latch value for channel 0 of module 03 and returns a response that the command was successful, with the data in engineering units format.	
Command	@03RH9
Response	?03
Attempts to read the high latch value for channel 9 of module 03 and returns a response that the command was unsuccessful because the channel 9 does not exist.	

※Related Commands: @AACH, @AACHi, @AARH

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.38 @AARL

Description
This command is used to read the low latch values for all channels of a specified module.

Syntax	
@AARL[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RL	The command to read the low latch values for all channels

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The low latch values for all channels. See Section 4 for details of the data format.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03RL
Response	!03-02.000+00.000+00.000+00.000+00.000+00.000+00.000+00.000
Reads the low latch values for module 03 and returns a response that the command was successful, with the data in engineering units format.	

※Related Commands: @AACL, @AACLi, @AARLi

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.39 @AARLCi

Description
This command is used to read the status of the low alarm for a specific channel of a specified module.

Syntax	
@AARLCi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RL	The command to read the status of the low alarm
Ci	The channel to be read, zero based

Response	
Valid Command	!AA(Data)S[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The status of the low alarm for a specific channel. See Section 4 for details of the engineering units format.
S	The alarm type: 0: Alarm Disabled 1: Momentary Alarm 2: Latched Alarm
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03LO-03.000C1L
Response	!03
Sets the low alarm limit for channel 1 of module 03 to -03.000 and sets the alarm type to latched, and returns a response indicating that the command was	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

successful.	
Command	@03RLC1
Response	!03-03.0002
Reads the status of the alarms for channel 1 of module 03 and returns a response indicating that the command was successful, and that the low alarm limit is -03.000 and the alarm type is latched.	

※Related Commands: @AALO(Data)CiT, @AADI, @AADLCi

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.2.40 @AARLi

Description
This command is used to read the low latch value for a specific channel of a specified module.

Syntax	
@AARLi[CHECKSUM](CR)	
@	Delimiter character
AA	The address of the module to be read in hexadecimal format (00 to FF)
RL	The command to read the low latch value
i	The channel to be read, zero based

Response	
Valid Command	!AA(Data)[CHECKSUM](CR)
Invalid Command	?AA[CHECKSUM](CR)
!	Delimiter character to indicate a valid command
?	Delimiter character to indicate an invalid command
AA	The address of the responding module in hexadecimal format (00 to FF)
(Data)	The low latch value for a specific channel. See Section 4 for details of the data format.
There will be no response if the command syntax is incorrect, there is a communication error, or there is no module with the specified address.	

Example	
Command	@03RL0
Response	!03-02.000
Reads the low latch value for channel 0 of module 03 and returns a response indicating that the command was successful, with the data in engineering units format.	
Command	@03RL9
Response	?03
Attempts to read the low latch value for channel 9 of module 03 and returns a response indicating that the command was unsuccessful because the channel 9 does not exist.	

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

※Related Commands: @AACL, @AACLi, @AARL

※Related Topics: Section 4 Analog Input Type and Data Format

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3 Modbus RTU Protocol Command set

The Modbus Protocol was developed by Modicon Inc., and was originally designed for Modicon controllers. Detailed information regarding the Modbus RTU Protocol can be found at:
http://www.modicon.com
and http://www.modbus.org

- Modbus RTU Command Format

Field 1	Field 2	Field 3	Field 4~n	Field n+1~n+2
Module Address	Function Code	Sub Function	Configuration Field	CRC16

Function Code	Description
0x04	Reads the input channels
0x46	Reads/writes the module settings

Examples:

A. To read the analog input value for module 01, the following command should be sent:
01 04 00 00 00 08 F1 CC

B. To read the name of the module, the following command should be sent:
01 46 00 12 60

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.1 Modbus Address Mapping

Address Mapping		
Address	Description	Attribute
00259	The filter settings. 0: 60Hz rejection 1: 50Hz rejection	R/W
00260	The Modbus Host Watchdog mode: 0: The same as I-7000 series modules 1: The AO and DO commands can be used to clear the status of the Host Watchdog timeout	R/W
00261	Enables or disabsle the Host Watchdog: 0: Disable 1: Enable	R/W
00269	The Modbus Data Format: 0: Hexadecimal 1: Engineering Units	R/W
00270	The Host Watchdog timeout status. Write 1 to clear.	W
00272	The factory calibration parameters. Write 1 to load.	W
00273	The Reset status: 0: This is not the first time the module has been read after being powered on 1: This is the first time the module has been read after being powered on	R
00280	The high latch values for all channels. Write 1 to clear.	W
00281	The low latch values for all channels. Write 1 to clear.	W
00513 ~ 00520	The high latch values for channels 0 to 7. Write 1 to clear.	W
00545 ~ 00552	The low latch values for channels 0 to 7. Write 1 to clear.	W
00577 ~	Enables or disables the high alarm for channels 0	R/W

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

00584	to 7: 0: Disable 1: Enable	
00609 ~ 00616	Enables or disables the low alarm for channels 0 to 7: 0: Disable 1: Enable	R/W
00641 ~ 00648	The high alarm mode for channels 0 to 7: 0: Momentary 1: Latch	R/W
00673 ~ 00680	The low alarm mode for channels 0 to 7: 0: Momentary 1: Latch	R/W
00705 ~ 00712	The status of the high alarms for channels 0 to 7	R/W
00737 ~ 00744	The status of the low alarms for channels 0 to 7	R/W
10129 ~ 10136	The under range status of channels 0 to 7 (supports types 0x7 and 0x1A only)	R
30001 ~ 30008	The analog input value for channels 0 to 7	R
30513 ~ 30520	The high latch value for channels 0 to 7	R
30545 ~ 30552	The low latch value for channels 0 to 7	R
40257 ~ 40264	The type code for channels 0 to 7	R/W
40481	The Firmware Version (Low Word)	R
40482	The Firmware Version (Ligh Word)	R
40483	The Module Name (Low Word)	R
40484	The Module Name (High Word)	R
40485	The Module Address. Valid Range: 1 ~ 247	R
40486	The Baud Rate: Bits 5:0 Baud Rate. Always set to 0x0A	R

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

	Bits 7:6 Reserved	
40489	The Host Watchdog timeout value. Valid range is 0 ~ 255, in 0.1 s intervals	R/W
40490	Enables or disables a specific channel	R/W
40492	The Host Watchdog timeout count. Write 0 to clear	R/W
40577 ~ 40584	The high alarm value for channels 0 to 7	R/W
40609 ~ 40616	The low alarm value for channels 0 to 7	R/W

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.2 PLC Address Mapping

Function Code	Description	Section
0x01	Reads the Coils	6.3.3
0x02	Reads discrete Inputs	6.3.4
0x03	Reads Multiple Registers	6.3.5
0x04	Reads Multiple Input Registers	6.3.6
0x05	Writes a Single Coil	6.3.7
0x06	Writes Multiple Registers	6.3.8
0x0F	Writes Multiple Coils	6.3.9
0x46	Reads/Writes the Module Settings	6.3.10

If the function specified in the message is not supported, then the module responds as below. Note that the address mapping for the Modbus protocol is Base 0.

Error Response

Number	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	Function code + 0x80
02	Exception Code	1	01

Note: If a CRC mismatch occurs, the module will not respond.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.3 01 (0x01) Reading the Coils

Description
This function code is used to read the current digital output readback values from the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x01
02~03	Starting Channel Number or Address Mapping	2	See Section 6.3.1 for details
04~05	Output Channel Number or Bit Count	2	0x0001 to 0x0020

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x01
02	Byte Count	1	Byte Count of the Response (B=(Bit Count + 7)/8)
03	Bit Values	B	(Bit Values)
Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x81
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.4 02 (0x02) Reading the Discrete Inputs

Description
This function code is used to read the current digital input values from the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function code	1	0x02
02~03	Starting Channel Number or Address Mapping	2	See Section 6.3.1 for details
04~05	Output Channel Number or Bit Count	2	0x0001 to 0x0020

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x02
02	Byte Count	1	Byte Count of the Response (B=(Bit Count + 7)/8)
03	Bit Values	B	(Bit Values)

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x82
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.5 03 (0x03) Reading Multiple Registers

Description
This function code is used to read the current digital input counter values from the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x03
02~03	Starting Channel Number or Address Mapping	2	See Section 6.3.1 for details
04~05	Output Channel Number or Bit Count	2	0x0001 to 0x0020

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x03
02	Byte Count	1	Byte Count of Response (B=2 * Word Count)
03~	Register Values	B*2	Register Values

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x83
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.6 04 (0x04) Reading Multiple Input Registers

Description
This function code is used to read the current digital input counter values from the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x04
02~03	Starting Channel Number or Address Mapping	2	See Section 6.3.1 for details
04~05	Output Channel Number or Bit Count	2	0x0001 to 0x0020

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x04
02	Byte Count	1	Byte Count of the Response (B=2 * Word Count)
03~	Register Values	B*2	Register Values

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x84
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.7 05 (0x05) Writing a Single Coil

Description
This function code is used to write the digital output value for the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x05
02~03	Starting Channel Number	2	See Section 6.3.1 for details
04~05	Output Value	2	A value of 0xFF00 sets the output to ON. A value of 0x0000 sets the output to OFF.

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x05
02~03	Output Channel Number	2	This value is the same as bytes 02 and 03 of the Request
04~05	Output Value	2	This value is the same as bytes 04 and 05 of the Request

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x85
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.8 06 (0x06) Writing Multiple Registers

Description
This function code is used to configure for the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x06
02~03	Address Mapping	2	See Section 6.3.1 for details
04~05	Register Value	2	Register Value

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x06
02~03	Address Mapping	2	The value is the same as bytes 02 and 03 of the Request
04~05	Register Value	2	Register value

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x86
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.9 15 (0x0F) Writing Multiple Coils

Description
This function code is used to write the digital output value for the ZT-2000 I/O module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x0F
02~03	Starting Cchannel Number	2	See Section 6.3.1 for details
04~05	Output Channel Number	2	0x0001 to 0x0020
06	Byte Count	1	B=(Bit Count + 7)/8
07	Output Value	2	A bit corresponds to a channel. When the bit is '1', it denotes that the configuration of the channel that was set is ON or Enable. If the bit is '0', it denotes that the configuration of the channel that was set is OFF or Disable.

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x0F
02~03	Starting Channel Number	2	The value is the same as bytes 02 and 03 of the Request
04~05	Input Channel Number	2	0x0001 ~ 0x0020

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x8F

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

6.3.10 70 (0x46) Reading/Writing the Module Settings

Description		
This function code is used to read the configuration settings from the module or to change the settings for the module. The following sub-function codes are supported.		
Sub-function Code	**Description**	**Section**
00 (0x00)	Reads the Name of the Module	A.1
04 (0x04)	Sets the Address of the Module	A.2
07 (0x07)	Reads the Type Code	A.3
08 (0x08)	Sets the Type Code	A.4
32 (0x20)	Reads the Firmware Version	A.5
37 (0x25)	Reads the Enabled/Disabled Status of a Specific Channel	A.6
38 (0x26)	Sets a Specific Channel to Enabled/Disabled	A.7
41 (0x29)	Reads the Miscellaneous Settings	A.8
42 (0x2A)	Writes the Miscellaneous Settings	A.9

If the module does not support the sub-function code specified in the message, then it will response as foolows:

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.1 00 (0x00) Reading the Name of a Module

Description
This sub-function code is used to read the name of a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-Function Code	1	0x00

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x00
03~06	Module Name	4	0x54 0x20 0x17 0x00(ZT-2017) 0x54 0x20 0x17 0x13(ZT-2017C)

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.2 04(0x04) Setting the Address of the Module

Description
This sub-function code is used to set the address fo the module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x04
03	New Address	1	1 to 247
04~06	Reserved	3	0x00 0x00 0x00

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x04
03	New Address	1	1 to 247
04~06	Reserved	3	0x00 0x00 0x00

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.3 07 (0x07) Reading the Type Code

Description
This sub-function code is used to read the type code information for a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x07
03	Reserved	1	0x00
04	Channel Number	1	0x00 to 0x07

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x07
03	Type Code	1	The Type Code. See Section 4 for details.

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.4 08 (0x08) Setting the Type Code

Description
This sub-function code is used to set the type code for a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x08
03	Reserved	1	0x00
04	Channel Number	1	0x00 ~ 0x07
05	Type Code	1	The Type Code. See Section 4 for details.

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x08
03	Type Code	1	0: OK Others: Error

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Example

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Command	01 46 20 [13 B8]
Response	01 46 20 01 00 00 [D2 05]

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.5 32 (0x20) Reading the Firmware Version Information

Description
This sub-function code is used to read the firmware version information for a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x20

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x20
03	Major Version	1	0x00 to 0xFF
04	Minor Version	1	0x00 to 0xFF
05	Reserved	1	0x00
06	Build Version	1	0x00 to 0xFF

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.6 37 (0x25) Reading the Channel Enabled/Disabled Status

Description
This sub-function code is used to read the enabled/disabled status for each channel of a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x25

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x25
03	Enabled/Disabled Status	1	0x00 to 0xFF. The enabled/disabled status of each channel, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that the channel is disabled, and 1 denotes that the channel is enabled.

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.7 38 (0x26) Enabling/Disabling a Channel

Description
This sub-function code is used to specify which channels of a module are to be enabled.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x26
03	Enabled/Disabled Settings	1	0x00 to 0xFF. The enabled/disabled settings for each channel, where bit 0 corresponds to channel 0, and bit 1 corresponds to channel 1, etc. When the bit is 0, it denotes that the channel is disabled, and 1 denotes that the channel is enabled.

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x26
03	Enabled/Disabled Settings	1	0: OK Others: Error.

Error Response

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.8 41 (0x29) Reading the Miscellaneous Settings

Description
This sub-function code is used to read the miscellaneous settings for a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x29

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x29
03	Miscellaneous Settings	1	The data format. See Section 4 for details.

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

A.9 42(0x2A) Writing the Miscellaneous Settings

Description
This sub-function code is used to configure the miscellaneous settings for a module.

Request			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x2A
03	Miscellaneous Settings	1	The data format. See Section 1.8 for details.

Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0x46
02	Sub-function Code	1	0x2A
03	Miscellaneous Settings	1	0: OK Others: Error

Error Response			
Byte	Description	Length	Value
00	Address	1	1 to 247
01	Function Code	1	0xC6
02	Exception Code	1	Refer to the Modbus standard for more details

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

7 Appendix

7.1 Software Configuration Mode

Each ZT-2000 I/O device contains a built-in EEPROM memory that is used to store configuration information, such as the address, the data format, the AI type code and other information. When the module is powered on with Address(Node ID) set to 0x00, the ZT-2000 I/O device will be set to the software configuration mode. In this mode, the configuration(Address(Node ID), data format and AI type code) are loaded from the EEPROM. The settings can then be changed using the %AANNTTCCFF, and $AA7CiRrr commands. When the ZT-2000 I/O device is set to software configuration mode, the switch settings are ignored.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

7.2 Dual Watchdog Operation

Dual Watchdog = Module Watchdog + Host Watchdog

The Module Watchdog is a hardware reset circuit that monitors the operating status of the module. While working in harsh or noisy environments, the module may be shut down by external signals. The Watchdog llows the module to operate continuously without disruption.

The Host Watchdog is a software function that monitors the operating status of the host. Its purpose is to prevent problems due to network/communication errors or host malfunctions. When a Host Watchdog timeout occurs, the module will reset all outputs to a safe state in order to prevent any erroneous operations of the controlled target.

ZT-2000 series devices include an internal Dual Watchdog, making the control system more reliable and stable.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

7.3 Reset Status

The reset status of a module is set when the module is powered-on, or when the module is reset by the Module Watchdog, and is cleared after responding to the first $AA5 command. This can be used to check whether the module has been previously reset. When the response to the $AA5 command indicates that the reset status has been cleared, it means that the module has not been reset since the last $AA5 command was sent. When the response to the $AA5 command indicates that the reset status has been set and it is not the first time the $AA5 command has been sent, it means that the module has been reset and the digital output value has been changed to the power-on value.

Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

8 Troubleshooting

(1) Technical Support.

If you have any difficulties using your ZT-2000 series I/O device, please send a description of the problem to service@icpdas.com


Include the following items in your email:

- *A description or diagram of the current DIP switch positions.*
- *A copy of the configuration file for the ZT-2000 coordinator. This file can be obtained using the procedure outlined below and should be attached to your email.*

a. Set the DIP switch of the ZT-255x device to the [ZBSET] position then reboot the device. Launch the ZT Configuration Utility and select [Save Log] icon to save the configuration of the ZT-255x as a file.



b. After clicking the [Save Log] icon, enter the “File Name” and the “File Path” in the Windows “Save” dialog box. Once the configuration has been successfully saved, the following message will be displayed.



Copyright © 2012 by ICP DAS Co., Ltd. All Rights Reserved.
Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000