

GW-2200 Series Quick Start

V1.0, Mar. 2020

What's in the box?

In addition to this guide, the package includes the following items:



GW-2200 Module x 1



Quick Start x1 (This Document)

Related Information

- GW Series Product Page:

https://www.icpdas.com/en/product/guide+Serial__Communication+Gateway+tGW__Modbus__Gateway#1183

- Documentation & Firmware:

https://www.icpdas.com/en/download/index.php?model=GW-2215i

- NS-205/NS-205PSE/M-7000 Product Page (optional):

https://www.icpdas.com/en/product/guide+Industrial__Communication+Ethernet__Communication+Ethernet__Switch#792

https://www.icpdas.com/en/product/guide+Remote__I_O__Module__and__Unit+RS-485__I_O__Modules+I-7000#462

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1 Connecting the Power and Host PC


1) Make sure your PC has workable network settings.


Disable or well configure your Windows firewall and Anti-Virus firewall first, else the “Search Servers” on Chapter 5 may not work. (Please contact with your system Administrator)

2) Connect both the GW-2200 and your PC to the same sub network or the same Ethernet switch.

3) Supply power (PoE or +12~+48 VDC) **to the GW-2200.**

⚠ **Note : Please use the first RJ-45 jack (ETH1) to connect the PoE Switch when using the PoE to power. The second RJ-45 jack (ETH2) doesn’t support the PoE function.**





Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

2 Installing Software on Your PC



Install eSearch Utility, which can be obtained from the web site:


https://www.icpdas.com/en/download/index.php?nation=US&kind1=&model=&kw=esearch

3 Wiring Notes


Wiring Notes for RS-232/485/422 Interfaces:

☑: Here, the RS-232 and RS-485 wiring is used as an example.


☑ RS-232 Wiring



☐ RS-422 Wiring



☑ RS-485 Wiring




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

4 Connecting the Modbus Devices


1) Connect the Modbus device (e.g., M-7022, optional) to the COM1 on GW-2200.
2) Supply power to the Modbus device (e.g., M-7022, Device ID:1).

Note: The wiring and supply power method depends on your Modbus device.

➢ **RS-485 Wiring**



➢ **RS-232 Wiring**




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5 Configuring Network Settings

1) Double-click the eSearch Utility shortcut on the desktop.

2) Click the **"Search Servers"** to search your GW-2200.


3) Double-click the name of GW-2200 to open the **"Configure Server (UDP)"** dialog box.



Factory Default Settings of GW-2200:

IP Address	192.168.255.1
Subnet Mask	255.255.0.0
Gateway	192.168.0.1

4) Contact your Network Administrator to obtain a correct network configuration (such as **IP/Mask/Gateway**). **Enter the network settings** and click **"OK"**. **Note: The GW-2200 will use the new settings 2 seconds later.**




Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

5) Wait 2 seconds and click **"Search Servers"** button again to ensure the GW-2200 is working well with new configuration.

6) Click the name of GW-2200 to select it.

7) Click the **"Web"** button to log in to the web configuration pages.
(Or enter the URL address of the GW-2200 in the address bar of the browser.)



6 Configuring the Serial Port

Note that if you intend to use Internet Explorer, ensure that the cache function is disabled in order to prevent browser access errors, please disable your Internet Explorer cache as follow: **(If you are not using IE browser, please skip this step.)**


Step1: Click **"Tools"** >> **"Internet Options…"** in the menu items.

Step 2: Click **"General"** tab and click the **"Settings…"** button in Temporary Internet files frame.

Step3: Click **"Every visit to the page"** and click the **"OK"** in Settings box and Internet Options box.

Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

1) Enter the password in the login password field and click **"Submit".**




2) Click the **"Port1"** tab to display the **"Port1 Settings"** page.

3) Select the appropriate **Baud Rate, Data Format and Modbus Protocol** (e.g., 19200, 8N2 and Modbus RTU) from the relevant drop down options.

Note: The Baud Rate, Data Format and Modbus protocol settings depends on your Modbus device.


4) Click **"Submit"** to save your settings.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000

7 Self-Test

1) In the eSearch Utility, select the **“Modbus TCP Master”** item from the **“Tools”** menu to open the Modbus TCP Master Utility.




2) In the Modbus TCP Modbus Utility, enter the IP address of GW-2200 and click **“Connect”** to connect the GW-2200.

3) Refer to **“Protocol Description”** section and type the Modbus command in the “Command” field then click **“Send command”**.

4) If the response data is correct, it means the test is success**.**

Note: The Modbus command settings depends on your Modbus device.



Distribuída no Brasil pela LRI | vendas@lri.com.br | 51 2129-3000